


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 1400LOCATION PS 234 M DATE 3/14/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<u>Outside</u>							
<u>750AM</u> <u>Outside Main Entrance</u>		<u>50.3</u>	<u>29.8</u>	<u>391</u>	<u>0</u>	<u>76</u>	<u>0</u>
<u>750AM</u> <u>Inside Main Entrance</u>		<u>70.9</u>	<u>30.3</u>	<u>470</u>	<u>0</u>	<u>36</u>	<u>0</u>
<u>South E Corner</u>		<u>60.1</u>	<u>30.0</u>	<u>395</u>	<u>0</u>	<u>48</u>	<u>0</u>
<u>South side</u>		<u>60.3</u>	<u>30.3</u>	<u>399</u>	<u>0</u>	<u>49</u>	<u>0</u>
<u>SW Corner</u>		<u>60.8</u>	<u>30.9</u>	<u>407</u>	<u>0</u>	<u>50</u>	<u>0</u>
<u>Playground</u>		<u>61.3</u>	<u>21.3</u>	<u>416</u>	<u>0</u>	<u>46</u>	<u>0</u>
<u>NW Corner</u>		<u>61.9</u>	<u>31.4</u>	<u>421</u>	<u>0</u>	<u>51</u>	<u>0</u>
<u>West side</u>		<u>62.0</u>	<u>30.0</u>	<u>401</u>	<u>0</u>	<u>50</u>	<u>0</u>
<u>NE Corner</u>		<u>62.4</u>	<u>29.6</u>	<u>399</u>	<u>0</u>	<u>50</u>	<u>0</u>
<u>Main Entrance</u>		<u>63.1</u>	<u>31.2</u>	<u>396</u>	<u>0</u>	<u>54</u>	<u>0</u>
<u>Guideline levels</u> <u>ASHRAE/AIHA/EPA</u>		<u>68 -75°F/winter</u> <u>73 -79°F/summer</u>	<u>30-60%</u>	<u>Outdoor level +</u> <u>700 ppm</u>	<u>9 ppm</u>	<u>65 ug/m³</u> <u>24-hour average</u>	<u>1 ppm</u>

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.


Signature:  Date: 3/14/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6TIME 1525LOCATION PS 234 M DATE 3/14/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
227 (Hall)		75.9	30.5	530	0	29	0
225		76.1	30.8	535	0	26	0
210		76.1	29.9	520	0	24	0
Hall by Stair 1		76.4	29.1	517	0	30	0
223 (Hall)		76.5	29.1	526	0	30	0
219 (Hall)		76.4	29.1	520	0	28	0
206		76.0	28.9	523	0	28	0
206 (Hall)		75.8	28.8	518	0	28	0
215 (Hall)		75.9	29.1	526	0	30	0
211		76.7	29.5	538	0	20	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/14/02

ATC ASSOCIATES, INC.

Page 3 of 6TIME 14:25

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS 234 MDATE 3/4/02PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Desk		78.0	28.0	601	0	44	0
Hall by Gym.		77.3	26.3	504	0	40	0
Gym.		76.2	27.6	541	0	44	0
Hall by Elevator.		75.3	27.5	539	0	42	0
Cafeteria (Window #3 OPEN)		80.7	28.9	606	0	48	0
Hall by Exit 1		75.0	27.5	511	0	44	0
114 (Hall)		74.8	27.7	520	0	46	0
116	2	75.5	29.5	558	0	49	0
118	—	75.5	29.5	543	0	46	0
20		75.8	31.0	530	0	45	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 3/4/02

CITY_21MC100_003083654

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6TIME 1510LOCATION PS 234 MDATE 3/14/02PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
122		73.9	29.9	532	0	48	0
Hall by Stair 3		73.1	30.6	567	0	47	0
222 (Hall)		71.7	31.5	535	0	32	0
222		73.0	31.5	593	0	30	0
220 (Hall)		74.3	31.6	580	0	32	0
218		75.3	31.2	510	0	28	0
216		75.6	31.6	535	0	27	0
212 (Hall)		76.0	31.1	526	0	29	0
229		75.7	30.6	520	0	26	0
229 (Hall)		75.6	30.7	536	0	24	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 3/14/02

CITY_21MC100_003083655

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 1545LOCATION PS 234 MDATE 3/14/02PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Stair 2		76.9	28.5	488	0	28	0
201		76.8	28.3	490	0	24	0
202		76.8	28.4	488	0	26	0
301		75.1	28.6	514	0	28	0
302		74.7	28.7	506	0	26	0
305		74.5	28.8	515	0	25	0
307(hall)		74.7	28.9	509	0	24	0
308		75.1	29.2	514	0	25	0
311		75.3	28.9	495	0	24	0
306		75.0	28.8	493	0	28	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/14/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1610LOCATION PS 234 M DATE 3/4/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
315		75.1	28.6	475	0	28	0
308 (HALL)		74.7	28.9	477	0	27	0
319		75.1	29.1	485	0	25	0
323		74.6	28.9	485	0	25	0
Hall by Stair 1		74.3	28.9	476	0	27	0
325		74.0	29.5	507	0	25	0
329		74.2	29.3	477	0	25	0
312 (HALL)		74.1	29.9	487	0	26	0
316		74.2	30.2	490	0	24	0
322		74.4	30.5	496	0	23	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/14/02

CITY_21MC100_003083657