


ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 1200LOCATION PS 234 M DATE 3/25/02 PROJECT NO. 19125-279

| Location                            | Occup. | Temperature (°F)                     | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|--------------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| Outside                             |        |                                      |                       |                            |                       |                                              |             |
| Main Entrance                       |        | 50.0                                 | 22.0                  | 373                        | 0                     | 16                                           | 0           |
| Main Desk Inside                    |        | 70.0                                 | 20.1                  | 469                        | 0                     | 8                                            | 0           |
| SW Corner                           |        | 53.1                                 | 20.1                  | 401                        | 0                     | 14                                           | 0           |
| West Side                           |        | 52.8                                 | 20.5                  | 399                        | 0                     | 16                                           | 0           |
| NW Corner                           |        | 52.5                                 | 20.9                  | 390                        | 0                     | 18                                           | 0           |
| Playground                          |        | 51.9                                 | 21.3                  | 398                        | 0                     | 15                                           | 0           |
| SE Corner                           |        | 51.6                                 | 21.5                  | 387                        | 0                     | 18                                           | 0           |
| NE Corner                           |        | 51.1                                 | 21.9                  | 384                        | 0                     | 19                                           | 0           |
| Main Entrance                       |        | 50.8                                 | 22.0                  | 389                        | 0                     | 13                                           | 0           |
| Courtyard                           |        | 50.5                                 | 22.3                  | 393                        | 0                     | 15                                           | 0           |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68 - 75°F/winter<br>73 - 79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature:  Date: 3/25/02

## ATC ASSOCIATES, INC.

Page 2 of 6

TIME 1220

## INDOOR AIR QUALITY FIELD REPORT


LOCATION PS 234 MDATE 3/25/02PROJECT NO. 19125 - 279

| Location                            | Occup. | Temperature (°F)                     | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ng/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|--------------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| Main Foyer                          |        | 77.4                                 | 16.9                  | 599                        | 0                     | 10                                           | 0           |
| Main Desk                           |        | 77.1                                 | 17.2                  | 658                        | 0                     | 13                                           | 0           |
| Hall by Gym                         |        | 76.4                                 | 17.4                  | 576                        | 0                     | 12                                           | 0           |
| Gym                                 | Full   | 75.4                                 | 18.0                  | 723                        | 0                     | 16                                           | 0           |
| Cafeteria                           |        | 78.6                                 | 15.5                  | 471                        | 0                     | 15                                           | 0           |
| Hall by Elevator                    |        | 74.8                                 | 16.2                  | 491                        | 0                     | 13                                           | 0           |
| Hall by Exit 1                      |        | 74.2                                 | 15.8                  | 484                        | 0                     | 20                                           | 0           |
| 114 (Hrtn)                          |        | 73.0                                 | 16.4                  | 481                        | 0                     | 16                                           | 0           |
| 116 (Hrtn)                          |        | 74.3                                 | 16.4                  | 537                        | 0                     | 15                                           | 0           |
| 118                                 | 23     | 75.0                                 | 19.8                  | 750                        | 0                     | 10                                           | 0           |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68 - 75°F/winter<br>73 - 79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: \_\_\_\_\_


Date: 3/25/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6TIME 1245LOCATION PS 234 MDATE 3/25/02PROJECT NO. 19125-279

| Location                            | Occup. | Temperature<br>(°F)                  | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates (ug/m <sup>3</sup> ) | TVOCs<br>(ppm) |
|-------------------------------------|--------|--------------------------------------|--------------------------|----------------------------|--------------------------|-------------------------------------------------|----------------|
| 120                                 | 1      | 75.4                                 | 18.9                     | 611                        | 0                        | 10                                              | 0              |
| 122                                 | 20     | 74.0                                 | 19.5                     | 754                        | 0                        | 13                                              | 0              |
| Hall (222)                          |        | 73.6                                 | 19.6                     | 650                        | 0                        | 11                                              | 0              |
| 222                                 | 18     | 73.9                                 | 18.7                     | 615                        | 0                        | 12                                              | 0              |
| 220                                 | 1      | 74.9                                 | 18.6                     | 627                        | 0                        | 11                                              | 0              |
| 218                                 | 18     | 74.7                                 | 17.2                     | 572                        | 0                        | 13                                              | 0              |
| 216                                 | 17     | 75.2                                 | 18.9                     | 728                        | 0                        | 13                                              | 0              |
| 212 (Hall)                          | -      | 75.6                                 | 18.6                     | 668                        | 0                        | 12                                              | 0              |
| 229                                 | 3      | 75.5                                 | 19.4                     | 703                        | 0                        | 9                                               | 0              |
| 227 (Hall)                          | -      | 75.7                                 | 19.1                     | 712                        | 0                        | 11                                              | 0              |
| Guideline levels<br>ASHRAE/AMIA/EPA |        | 68 - 75°F/winter<br>73 - 79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average         | 1 ppm          |

Comments: \_\_\_\_\_


The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/25/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6TIME 1310LOCATION PS 234 M DATE 3/25/02 PROJECT NO. 19125-279

| Location                            | Occup. | Temperature (°F)                   | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|------------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| 225                                 | 17     | 76.1                               | 21.0                  | 800                        | 0                     | 10                                           | 0           |
| 210 (Hall)                          | —      | 76.0                               | 19.4                  | 735                        | 0                     | 12                                           | 0           |
| 223                                 | 25     | 78.3                               | 19.7                  | 754                        | 0                     | 11                                           | 0           |
| Hall by Elevator                    | —      | 77.9                               | 19.2                  | 754                        | 0                     | 12                                           | 0           |
| 219                                 | 22     | 77.4                               | 18.8                  | 657                        | 0                     | 10                                           | 0           |
| 206 (Hall)                          |        | 77.2                               | 18.6                  | 696                        | 0                     | 14                                           | 0           |
| 206                                 |        | 76.3                               | 18.7                  | 708                        | 0                     | 11                                           | 0           |
| 215                                 | 1      | 79.4                               | 19.2                  | 750                        | 0                     | 9                                            | 0           |
| 211                                 | 25     | 79.0                               | 20.2                  | 849                        | 0                     | 9                                            | 0           |
| 207 (Hall)                          |        | 76.7                               | 19.9                  | 841                        | 0                     | 9                                            | 0           |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/25/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 5:35LOCATION PS 234 MDATE 3/25/02PROJECT NO. 19125 - 279

| Location                            | Occup. | Temperature (°F)                     | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|--------------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| Hall by Stair 2                     |        | 78.7                                 | 19.3                  | 829                        | 0                     | 8                                            | 0           |
| 201                                 | 1      | 77.0                                 | 17.9                  | 699                        | 0                     | 8                                            | 0           |
| 202                                 |        | 77.3                                 | 17.9                  | 725                        | 0                     | 8                                            | 0           |
| 201 (Hall)                          |        | 77.3                                 | 17.9                  | 750                        | 0                     | 7                                            | 0           |
| 302 (Hall)                          |        | 76.5                                 | 20.0                  | 903                        | 0                     | 13                                           | 0           |
| 301                                 |        | 76.0                                 | 19.2                  | 828                        | 0                     | 7                                            | 0           |
| 305                                 |        | 75.6                                 | 18.9                  | 790                        | 0                     | 8                                            | 0           |
| 304                                 |        | 76.1                                 | 23.9                  | 1060                       | 0                     | 14                                           | 0           |
| 311                                 |        | 75.3                                 | 18.8                  | 744                        | 0                     | 7                                            | 0           |
| 306                                 | 4      | 75.3                                 | 19.9                  | 869                        | 0                     | 10                                           | 0           |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68 - 75°F/winter<br>73 - 79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: \_\_\_\_\_

Date: 3/25/02

CITY\_21MC100\_003083726

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1555LOCATION PS 234 M DATE 3/25/02 PROJECT NO. 19125 - 279

| Location                            | Occup. | Temperature (°F)                     | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|--------------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| 315                                 |        | 75.9                                 | 18.4                  | 728                        | 0                     | 9                                            | 0           |
| 308                                 |        | 74.9                                 | 19.2                  | 1035                       | 0                     | 10                                           | 0           |
| 319 (H411)                          |        | 74.7                                 | 19.3                  | 825                        | 0                     | 10                                           | 0           |
| 323                                 |        | 74.3                                 | 18.4                  | 728                        | 0                     | 9                                            | 0           |
| 325                                 |        | 74.0                                 | 18.5                  | 713                        | 0                     | 9                                            | 0           |
| 329                                 | 18     | 75.5                                 | 19.0                  | 757                        | 0                     | 9                                            | 0           |
| 316                                 | 1      | 75.1                                 | 16.4                  | 572                        | 0                     | 9                                            | 0           |
| 318                                 | 3      | 74.5                                 | 15.4                  | 533                        | 0                     | 11                                           | 0           |
| 320                                 |        | 74.3                                 | 16.0                  | 537                        | 0                     | 9                                            | 0           |
| 322                                 | 1      | 74.0                                 | 16.3                  | 559                        | 0                     | 10                                           | 0           |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68 - 75°F/winter<br>73 - 79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: *Gilch* Date: 3/25/02