

ATC Associates

104 East 25 Street New York NY 10010

Phone (212) 353-8280

Fax (212) 353 8306



Attn Mr Bernard Orlan
 N Y C Board of Education
 28 11 Queens Plaza North
 Long Island City NY 11101

Received 4/11/02 9 30 00 PM
 ATC Group # 7385
 Analysis Date 4/11/02

Fax (212) 475 4122 Phone (212) 477 8941

Project H S for Leadership & Public Service
 90 Trinity Place NY NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0 5µ 5	5µ		(S/mm)	(S/cc)	
04 7385 1	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
05 7385 2	1832 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
06 7385 3	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
07 7385 4	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
08 7385 5	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
09 7385 6	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
10 7385 7	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

ROMAN PEYSAKHOV

Analyzed by

MICHAEL A GORYCKI Ph D

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel. This lab is only responsible for data reported in structures/mm. This report may not be reproduced except in full without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government. This report relates only to the samples reported above. Quality control data (including 95 % confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0 NY State ELAP #10879

Attn Mr Bernard Orlan
 N Y C Board of Education
 28 11 Queens Plaza North
 Long Island City NY 11101
 Fax (212) 475 4122 Phone (212) 477 8941
 Project H S for Leadership & Public Service
 90 Trinity Place NY NY

Received 4/11/02 9 30 00 PM
 ATC Group # 7385
 Analysis Date 4/11/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm) (S/cc)	Notes
11 7385 8	1816 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	
12 7385 9	1824 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	
13 7385 10	1816 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	
14 7385 11	1816 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	
15 7385 12	1808 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	
16 7385 13	1824 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	
17 7385 14	1824 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	
18 7385 15	1808 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	
19 7385 16	1816 00	0 0450	0	None Detected	0 0	0 0047	<22 24 <0 0047	

ROMAN PEYSAKHOV

Analyzed by



MICHAEL A GORYCKI Ph D

Approved by



Disclaimer: The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel. This lab is only responsible for data reported in structures/mm. This report may not be reproduced except in full without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187 0 NY State ELAP #10879

Page 2 of 3

CITY_21MC100_003085899

Attn: Mr. Bernard Orlan
 N Y C Board of Education
 28 11 Queens Plaza North
 Long Island City NY 11101

Received 4/11/02 9 30 00 PM
 ATC Group # 7385
 Analysis Date 4/11/02

Fax (212) 475 4122 Phone (212) 477 8941

Project H S for Leadership & Public Service
 90 Trinity Place NY NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ	5µ		(S/mm)	(S/cc)	
20 7385 17	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 7385 18	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


ROMAN PEYSAKHOV

Analyzed by



MICHAEL A. GORYCKI Ph.D.

Approved by



Disclaimer: The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel. This lab is only responsible for data reported in structures/mm. This report may not be reproduced except in full without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

Page of 3

CITY_21MC100_003085900

ROMAN PEYSAKHOV

	F	B	C	M	5μ
Chrysotile					
Amphibole					
Ambiguous					
Non Asbestos					
Non Identified					

