NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street New York NY 10010

Phone (212) 353 8280 Fax (212) 353 8306

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101
Fax (212) 475 4122 **Phone** (212) 477 8941
Project H S for Leadership & Public Service

Received 4/18/02 9 30 00 PM
ATC Group # 7459
Analysis Date 4/18/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0 5μ*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
04 *7459 1*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
05 *7459 2*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
06 *7459 3*	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
07 *7459 4*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
08 *7459 5*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
09 *7459 6*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
10 *7459 7*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

MARK PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government. This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

CITY_21MC100_003086073

NYC-WTC_000189348

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101
Fax (212) 475 4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service

Received 4/18/02 9 30 00 PM
ATC Group # 7459
Analysis Date 4/18/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0 5μ	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
11 7459 8	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
12 7459~9	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
13 7459 10	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
14 7459 11	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
15 7459 12	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
16 7459 13	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
17 7459 14	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
18 7459 15	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
19 7459 16	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

MARK PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187 0 NY State ELAP #10879

Attn	Mr Bernard Orlan	**Received**	4/18/02 9 30 00 PM
	N Y C Board of Education	**ATC Group #**	7459
	28 11 Queens Plaza North	**Analysis Date**	4/18/02
	Long Island City NY 11101		
Fax	(212) 475 4122 **Phone** (212) 477 8941		
Project	H S for Leadership & Public Service		

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0 5μ*	*5 5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
20 *7459 17*	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
21 *7459 18*	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

MARK PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187 0 NY State ELAP #10879