



104 East 25th St
 New York, New York 10010
 www.atc-enviro.com
 212 353 8280
 Fax 212 353 8306

January 28, 2002

Mr. Bernard P. Orlan
 Director, Environmental Health & Safety
 New York City Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101-4008

**Re: Wipe Samples for Polychlorinated Biphenyls &
 Polynuclear Aromatic Hydrocarbons
 High School for Leadership & Public Service
 90 Trinity Place
 New York, New York
 ATC Project No. 15-19125-0290**

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of the results of the wipe samples for polychlorinated biphenyls (PCBs) and polynuclear aromatic hydrocarbons (PAHs) collected on January 2, 2002, at the referenced location. The New York City Board of Education (BOE) requested these samples to evaluate possible contamination in the school building.

SCOPE OF WORK

Tenzin Namgyal and Wagdi Abdelshahid, Industrial Hygienists of ATC's New York City office, collected the samples.

The samples were collected using sterile gauze pads and hexane as a solvent. The solvent was provided and samples were analyzed by PSC Analytical Services, Inc. (PSC), an American Industrial Hygiene Association-accredited laboratory in Reading, PA. The PCB analysis was performed using EPA Method 8082B. The PAHs were analyzed by EPA Method 8270C.

The sampling was performed consistent with generally accepted industrial hygiene practices. There were inherent limitations created by constraints of time, operational and work practice variability, variations in contaminant concentrations, and sampling and analytical accuracy. The results of the sampling represent conditions found on the dates the samples were collected.

WIPE SAMPLING RESULTS

ATC submitted eight samples for PCBs and PAHs to PSC for analysis. A blank was also submitted. A copy of the laboratory report is provided in the Attachment. Samples were taken from surfaces throughout the building. The sample area for each wipe sample was 100 square centimeters (100cm²).

Mr. Bernard P. Orlan
Wipe Sampling for PCBs and PAHs
H. S. for Leadership & Pub. Service (894M)

January 28, 2002
Page 2
ATC Project No. 15-19125-0290

The areas sampled were

- Cafeteria serving window;
- Library table (north);
- Room 1106 floor (south);
- Room 903 floor (north);
- Room 715 table (south);
- Room 503 table (north);
- Hallway floor by Stair B;
- 1st floor Main Lobby floor.

Each sample was analyzed for seven (7) PCB compounds and sixteen (16) PAHs (see attachment). *The PCB and PAH results of all samples collected were below the reporting limits of 2.0 and 5.0 micrograms/sample (ug / sample) respectively.*

Currently, the Environmental Protection Agency spill clean-up standard for PCBs on non-porous surfaces is 10 micrograms per 100 square centimeters or less ($<10\text{ug}/100\text{cm}^2$) as stated in 40 CFR 761. No regulatory standards have been established for PAHs on surfaces.

It is our pleasure to provide these indoor environmental services to the New York City Board of Education. If you have any questions about this report, please call (212) 353-8280, extension 212 or 261.

Sincerely,
ATC ASSOCIATES INC.



James R. Cohn, CIH, CSP
Regional Manager
Industrial Hygiene Division

Attachment