NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY

Received: 5/12/02 4:00:00 PM
ATC Group #: 7718
Analysis Date: 5/12/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
1 *7718 -1*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
2 *7718 -2*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
3 *7718 -3*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
4 *7718 -4*	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
5 *7718 -5*	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
6 *7718 -6*	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
7 *7718 -7*	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003090314

NYC-WTC_000191141

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY

Received: 5/12/02 4:00:00 PM
ATC Group #: 7718
Analysis Date: 5/12/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
8 *7718 -8*	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
9 *7718 -9*	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
10 *7718 -10*	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
11 *7718 -11*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
12 *7718 -12*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
13 *7718 -13*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
14 *7718 -14*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
15 *7718 -15*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
16 *7718 -16*	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003090315

NYC-WTC_000191142

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY

Received: 5/12/02 4:00:00 PM
ATC Group #: 7718
Analysis Date: 5/12/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Ash*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
17 *7718 -17*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
18 *7718 -18*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
19 *7718 -19*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
20 *7718 -20*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
21 *7718 -21*	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003090316

NYC-WTC_000191143