

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/15/02 4:00:00 PM
 ATC Group #: 8121
 Analysis Date: 6/15/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µ	5µ		(S/mm ²)	(S/cc)	
1 8121 -1	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
2 8121 -2	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
3 8121 -3	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
4 8121 -4	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
5 8121 -5	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
6 8121 -6	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
7 8121 -7	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/15/02 4:00:00 PM
 ATC Group #: 8121
 Analysis Date: 6/15/02

Fax: (212)-475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
8 8121 -8	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
9 8121 -9	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
10 8121 -10	1960.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
11 8121 -11	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
12 8121 -12	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
13 8121 -13	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
14 8121 -14	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
15 8121 -15	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
16 8121 -16	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044

ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/15/02 4:00:00 PM
 ATC Group #: 8121
 Analysis Date: 6/15/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5 μ -5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
17 8/21 -17	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
18 8/21 -18	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
19 8/21 -19	1960.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
20 8/21 -20	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
21 8/21 -21	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879