

Laboratory Report & Chain of Custody For Lead-in-dust wipes



High School for Leadership & Public Service (M894)
May 17, 2002

CITY_21MC100_003093978

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 05-16-02

CLIENT: NYC BOE

PROJECT ADDRESS: M894/90 Trinity Place
NY, NY 10006

PROJECT NO: 41617-0561

SAMPLED BY: Y. Efstathiou

SAMPLE DATE: 05-16-02

DATE RECEIVED: 05-16-02

DATE ANALYZED: 05-16-02

SAMPLE MEDIA: Dust Wipe Sample

ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
01	9818	Blank	<9.0 µg	9.0 µg
02	9818	1st Floor Lobby (Floor)	<9.0	9.0
03	9818	Auditorium (Floor)	<9.0	9.0
04	9818	Cafeteria (Floor)	<9.0	9.0
05	9818	Classroom #906 (Floor)	<9.0	9.0
06	9818	13th Floor Hallway (Floor)	<9.0	9.0
07	9818	9th Floor Hallway (Floor)	<9.0	9.0
08	9818	7th Floor Hallway (Floor)	<9.0	9.0
09	9818	5th Floor Hallway (Floor)	<9.0	9.0
10	9818	Classroom #503 (Window Sill)	<7.9	7.9
11	9818	3rd Floor Hallway (Floor)	<9.0	9.0

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: IL

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).