

Laboratory Report & Chain of Custody For Lead-in-dust wipes



*High School for Leadership & Public Service (M894)
June 21, 2002*

CITY_21MC100_003094006

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 06-20-02

CLIENT: NYC BOE

PROJECT ADDRESS: M 894 / 90 Trinity Place
New York, NY 10006

PROJECT NO: 41617-0561

SAMPLED BY: Y. Efstathiou

SAMPLE DATE: 06-20-02
DATE RECEIVED: 06-20-02
DATE ANALYZED: 06-20-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
01	9857	Blank	<9.0 µg	9.0 µg
02	9857	1st Floor Lobby Floor	<9.0	9.0
03	9857	Cafeteria Floor	<9.0	9.0
04	9857	13th Floor Hallway Floor	<9.0	9.0
05	9857	9th Floor Hallway Floor	<9.0	9.0
06	9857	Classroom 906 Floor	<9.0	9.0
07	9857	7th Floor Hallway	<9.0	9.0
08	9857	5th Floor Hallway	<9.0	9.0
09	9857	Classroom 503 Window Sill	<7.9	7.9
10	9857	3rd Floor Hallway	<9.0	9.0
11	9857	Auditorium Floor	<9.0	9.0

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: IL

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).