

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/2/02 6:00:00 PM
ATC Group #: 7937
Analysis Date: 6/2/02

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µ	5µ		(S/mm²)	(S/cc)	
04 7937 -1	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 7937 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 7937 -3	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 7937 -4	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 7937 -5	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
09 7937 -6	1872.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
10 7937 -7	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/2/02 6:00:00 PM
 ATC Group #: 7937
 Analysis Date: 6/2/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
11 7937 -8	1872.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
12 7937 -9	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
13 7937 -10	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
14 7937 -11	1888.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
15 7937 -12	1896.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
16 7937 -13	1896.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
17 7937 -14	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
18 7937 -15	1872.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
19 7937 -16	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-3, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/2/02 6:00:00 PM
 ATC Group #: 7937
 Analysis Date: 6/2/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
20 7937 -17	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 7937 -18	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879