

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 5/29/02 9:00:00 PM
ATC Group #: 7902
Analysis Date: 5/30/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5.0µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
1 7902 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
2 7902 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
3 7902 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
4 7902 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
5 7902 -5	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
6 7902 -6	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
7 7902 -7	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Received: 5/29/02

9:00:00 PM

ATC Group #: 7902

Analysis Date: 5/30/02


Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
8 7902 -8	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
9 7902 -9	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
10 7902 -10	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
11 7902 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
12 7902 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
13 7902 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
14 7902 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
15 7902 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
16 7902 -16	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 5/29/02 9:00:00 PM
 ATC Group #: 7902
 Analysis Date: 5/30/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5.5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
17 7902 -17	1920.00	0.0450	0	None Detected	0 0	0.0045	<22.24	<0.0045	
18 7902 -18	1920.00	0.0450	0	None Detected	0 0	0.0045	<22.24	<0.0045	
19 7902 -19	1920.00	0.0450	0	None Detected	0 0	0.0045	<22.24	<0.0045	
20 7902 -20	1920.00	0.0450	0	None Detected	0 0	0.0045	<22.24	<0.0045	
21 7902 -21	1928.00	0.0450	0	None Detected	0 0	0.0044	<22.24	<0.0044	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879