NYC 9/11 Public Portal Document

ATTACHMENT

IAQ FIELD DATA COLLECTION FORMS

NYC-WTC_000194797

NYC 9/11 Public Portal Document

TIME 830

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 M DATE 02·03·02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
Lobby		72.1	20.0	610	0	5	0
Room #2		72.3	19.0	478	0	5	0
Room #3		70.7	18.5	568	0	4	0
Resource Room		72.6	18.8	529	0	6	0
Nurse Room		72.0	16.9	508	0	4	0
Multi Purpose Room		73.1	19.3	402	0	9	0
Kithen		72.9	18.1	463	0	7	0
Room #404		73.7	18.6	439	0	6	0
Room #403		73.0	18.8	508	0	5	0
Room # 402		72.8	18.1	495	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: Tim Austin/ATC Date: 02·03·02

CITY_21MC100_0041151738

NYC-WTC_000194798

NYC 9/11 Public Portal Document

TIME 910

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 M DATE 02·03·02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOC (ppm)
Room #401		72.0	15.2	437	0	6	0
Room #501		69.9	15.0	439	0	4	0
Room #502		69.5	14.8	446	0	11	0
Room #503		69.3	15.6	517	0	18	0
Room #504		69.2	19.7	460	0	27	0
Entrance 1 FL		73.7	18.4	507	0	5	0
outside East side		42.2	20.1	441	0	6	0
outside South side		42.1	19.5	430	0	4	0
outside west side		41.9	19.8	422	1	5	0
outside North side		42.3	20.6	430	0	4	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) (✓) Does ( ) Does not meet established indoor air quality guidelines.

Signature: Tim Anastasiou Date: 02·03·02

CITY_21MC100_0041517 39

NYC-WTC_000194799

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1210

LOCATION PS150 M DATE 02.03.02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOC (ppm)
Room #401		72.5	15.5	450	0	4	0
Room #501		71.0	16.0	444	0	9	0
Room #502		68.9	15.1	521	0	13	0
Room #503		69.6	16.3	455	0	20	0
Room #504		69.9	20.1	498	0	29	0
Entrance 1FL		74.1	18.4	438	0	5	0
outside East side		43.2	19.0	453	0	4	0
outside South side		43.1	19.2	457	1	4	0
outside west side		43.2	18.9	455	0	5	0
outside North side		43.3	19.2	453	0	4	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: Tim Anstis/ousley Date: 02.03.02

CITY_21MC100_00415174O

NYC-WTC_000194800

NYC 9/11 Public Portal Document

TIME 1130

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 M DATE 02·03·02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
Lobby		71.9	19.8	601	0	5	0
Room #2		72.1	19.5	469	0	6	0
Room #3		70.9	18.9	572	0	4	0
Resoice Room		71.9	18.3	531	0	5	0
Nurse Room		72.3	16.6	511	0	6	0
Multi Purpose Room		73.5	20.1	472	0	11	0
kithen		73.1	17.9	466	0	6	0
Room #404		73.5	18.5	432	0	4	0
Room #403		73.2	19.1	505	0	5	0
Room # 402		72.5	17.9	501	0	7	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) (✓) Does ( ) Does not meet established indoor air quality guidelines.

Signature: Tim Austislovsky Date: 02·03·02

CITY_21MC100_004151741

NYC-WTC_000194801