

ATTACHMENT
IAQ FIELD DATA COLLECTION FORMS

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4TIME 1200LOCATION PS150 MDATE 3/14/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOC (ppm)
Outside							
SE Corner		66.0	28.9	380	0	50	0
South Side		66.3	28.5	382	0	52	0
East Side		66.8	28.0	386	0	50	0
East Top of Stairs		67.3	27.8	383	0	50	0
Main Entrance		66.6	27.5	380	0	48	0
North Top of Stairs		66.4	27.0	385	0	49	0
North Side		66.0	26.8	396	0	48	0
NE Corner		65.4	27.3	390	0	50	0
NW Corner		65.8	27.9	387	0	46	0
West Side		65.6	28.9	381	0	48	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: Working in the Courtyard

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jeniffer Date: 3/14/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4

TIME 1230

LOCATION PS150 M

DATE 3/14/02

PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer		76.1	30.4	575	0	43	0
Hall by West Stairs		76.0	30.3	600	0	40	0
Main Desk		75.8	31.3	618	0	43	0
Ed's Rm.		75.7	31.1	616	0	37	0
Main Lobby Area		75.8	31.5	616	0	40	0
Guidance Rm		75.5	29.5	543	0	38	0
Main Office		75.7	28.7	548	0	35	0
Hall by Girls Rm		75.8	30.5	550	0	40	0
Hall by Boy Rm		76.0	30.6	569	0	39	0
Hall by East Stairs		76.3	30.8	576	0	39	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.



Signature:  Date: 3/14/02

CITY_21MC100_004151955

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1300LOCATION PS150 MDATE 3/14/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Slop Sink		76.7	31.2	591	0	43	0
Resource Rm		77.0	30.7	573	0	43	0
Nurse Rm		77.4	30.5	552	0	45	0
Kitchen Area.		77.6	30.4	614	0	43	0
Music Rm		77.6	31.4	666	0	46	0
404		77.5	29.9	588	0	38	0
404 (HALL)		77.5	29.5	529	0	36	0
403		77.6	29.6	527	0	34	0
Hall by Rest Rms		77.8	29.9	535	0	36	0
Hall by Staff Rm		77.8	30.2	528	0	25	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Date: 3/14/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1330LOCATION PS150 MDATE 3/14/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOC (ppb)
402		76.9	27.4	497	40	30	0
402 (Hall)		77.0	28.4	516	0	38	0
401		76.6	28.8	521	0	40	0
Hall by West Stairs		76.9	28.6	515	0	39	0
501		77.1	30.2	580	0	30	0
502		77.3	29.4	571	0	28	0
502 (Hall)		77.6	28.9	573	0	36	0
Hall by Rest Rm		77.5	29.1	575	0	40	0
503		76.8	28.7	560	0	30	0
504		76.6	28.5	551	0	29	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 3/14/02

CITY_21MC100_004151957