

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 04-16-02
CLIENT: NYC BOE
PROJECT ADDRESS: P.S. 150M/334 Greenwich Street
NY, NY 10013
PROJECT NO: 41717-0556
SAMPLED BY: M. Nakhumovich
SAMPLE DATE: 04-15-02
DATE RECEIVED: 04-15-02
DATE ANALYZED: 04-15-02
SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
01	9765	1st Floor Lobby Floor	14.1	9.0
02	9765	Multipurpose Room Floor	<9.0	9.0
03	9765	R#503 Window Sill	<6.5	6.5
04	9765	R#403 Floor	10.0	9.0
05	9765	Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg