

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 02-12-02

CLIENT: NYC BOE

PROJECT ADDRESS: P.S. 150M/334 Greenwich Street, NY, NY 10013
NY, NY

PROJECT NO: 41617-0556

SAMPLED BY: M. Medinets

SAMPLE DATE: 02-11-02
DATE RECEIVED: 02-11-02
DATE ANALYZED: 02-11-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT
01	9666	Classroom #503 Window Sill	<6.2	6.2
02	9666	Classroom #404 Floor	<9.0	9.0
03	9666	Multipurpose Room Floor	<9.0	9.0
04	9666	1st Floor Lobby Floor	<9.0	9.0
05	9666	Blank	<9.0	9.0

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$,
Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306


CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: 

REPORT PREPARED BY: 

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: 

LABORATORY DIRECTOR: 

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).