

INDOOR AIR QUALITY ANALYSIS

Project: Newmark & Co. Real Estate, Inc.
100 Gold Street

CTSI Project #: NY-442-01

Date: November 8, 2001

LOCATION	TEMPERATURE (°F)	RELATIVE HUMIDITY (RH%)	CO ₂ (PPM)	CO (PPM)	TOTAL PARTICULATE LEVELS
	Standard = 68-74°F	Standard = 30-50%	Standard = 1,000 PPM	Standard = 9.0 PPM	Standard = 0.015 mg/m ³
Outside	59.0	39.5	366	1.5	0.030
9 th Fl. Section-A	71.2	29.4	551	1.1	<0.001
9 th Fl. Section-M	72.4	28.1	592	1.0	<0.001
9 th Fl. Section-Z	72.6	28.3	623	1.0	<0.001
9 th Fl. Section-O	73.6	26.7	504	1.1	<0.001
8 th Fl. Section-A	74.8	26.3	630	1.1	<0.001
8 th Fl. Section-M	75.3	26.3	607	1.1	<0.001
8 th Fl. Section-Z	75.1	26.9	678	1.1	<0.001
8 th Fl. Section-O	74.9	26.5	595	1.1	<0.001
7 th Fl. Section-A	75.9	25.5	558	1.1	<0.001
7 th Fl. Section-M	76.0	26.0	640	1.1	<0.001
7 th Fl. Section-Z	76.6	25.9	622	1.1	<0.001
7 th Fl. Section-O	76.5	25.3	583	1.2	<0.001
6 th Fl. Section-A	76.3	25.5	554	1.2	<0.001
6 th Fl. Section-M	76.0	26.0	602	1.1	<0.001
6 th Fl. Section-Z	76.0	26.6	678	1.2	<0.001
6 th Fl. Section-O	75.7	26.1	615	1.2	<0.001

°F = degrees Fahrenheit CO = Carbon monoxide CO₂ = Carbon dioxide PPM = Parts Per Million
RH = Relative humidity ND = Non Detected

CITY_21MC100_003181131



INDOOR AIR QUALITY ANALYSIS

Project: Newmark & Co. Real Estate, Inc.
100 Gold Street

CTSI Project #: NY-442-01

Date: November 8, 2001

LOCATION	TEMPERATURE (°F)	RELATIVE HUMIDITY (RH%)	CO ₂ (PPM)	CO (PPM)	TOTAL PARTICULATE LEVELS
	Standard = 68-74°F	Standard = 30-50%	Standard = 1,000 PPM	Standard = 9.0 PPM	Standard = 0.015 mg/m ³
5 th Fl. Section-A	76.1	25.4	550	1.1	<0.001
5 th Fl. Section-M	75.7	25.6	539	1.0	<0.001
5 th Fl. Section-Z	76.7	25.4	636	1.1	<0.001
5 th Fl. Section-O	77.7	24.4	686	1.1	<0.001
4 th Fl. Section-A	77.8	24.9	595	1.1	<0.001
4 th Fl. Section-M	77.5	25.2	621	1.1	<0.001
4 th Fl. Section-Z	75.1	26.7	590	1.2	<0.001
4 th Fl. Section-O	75.2	26.7	561	1.1	<0.001
3 rd Fl. Section-A	75.7	26.2	582	1.2	<0.001
3 rd Fl. Section-M	75.8	26.4	619	1.1	<0.001
3 rd Fl. Section-Z	75.7	26.5	624	1.1	<0.001
3 rd Fl. Section-O	76.3	26.2	568	1.1	<0.001
1 st Fl. Section-Z	71.4	31.8	650	1.3	<0.001
1 st Fl. Section-M	71.1	31.5	628	1.1	<0.001
1 st Fl. Lobby	73.5	30.8	813	1.2	0.008

°F = degrees Fahrenheit CO = Carbon monoxide CO₂ = Carbon dioxide PPM = Parts Per Million
RH = Relative humidity ND = Non Detected