

INDOOR AIR QUALITY ANALYSIS

Project: Newmark & Co. Real Estate, Inc.
100 Gold Street

CTSI Project #:NY-442-01 Date: October 30, 2001

LOCATION	TEMPERATURE (°F)	RELATIVE HUMIDITY (RH%)	CO ₂ (PPM)	CO (PPM)	TOTAL PARTICULATE LEVELS
	Standard = 68-74°F	Standard = 30-50%	Standard = 1,000 PPM	Standard = 0 - 9.0 PPM	Standard= 50 ug/m ³
1 st Fl. Lobby	77.0	26.8	672	ND	13
Outside	6.7	27.2	466	ND	30
9 th Fl.-A	71.9	28.9	575	ND	1
9 th Fl.-M	73.5	26.4	583	ND	3
9 th Fl.-Z	73.7	27.2	571	ND	1
9 th Fl.-O	74.8	26.7	533	ND	1
8 th Fl.-A	75.8	27.2	631	ND	2
8 th Fl.-M	75.9	26.1	587	ND	2
8 th Fl.-Z	75.4	26.9	670	ND	2
8 th Fl.-O	75.8	26.3	679	ND	1
7 th Fl.-A	76.5	25.6	608	ND	2
7 th Fl.-M	76.9	25.0	587	ND	3
7 th Fl.-Z	76.1	25.7	638	ND	2
7 th Fl.-O	75.6	25.3	556	ND	1
6 th Fl.-A	76.8	25.9	562	ND	1
6 th Fl.-M	76.9	23.9	609	ND	3
6 th Fl.-Z	75.8	26.0	664	ND	7
6 th Fl.-O	75.8	25.4	584	ND	1

°F = degrees Fahrenheit CO = Carbon monoxide CO₂ = Carbon dioxide PPM = Parts Per Million
RH = Relative humidity ND = Non Detected



INDOOR AIR QUALITY ANALYSIS

Project: Newmark & Co. Real Estate, Inc.
100 Gold Street

CTSI Project #: NY-442-01 Date: October 30, 2001

LOCATION	TEMPERATURE (°F)	RELATIVE HUMIDITY (RH %)	CO ₂ (PPM)	CO (PPM)	TOTAL PARTICULATE LEVELS
	Standard = 68-74°F	Standard = 30-50%	Standard = 1,000 PPM	Standard = 9.0 PPM	Standard = 50 ug/m ³
5 th Fl.-A	75.8	24.8	610	ND	1
5 th Fl.-M	76.0	23.0	513	ND	3
5 th Fl.-Z	76.6	25.3	585	ND	2
5 th Fl.-O	76.8	23.4	574	ND	1
4 th Fl.-A	77.3	24.8	650	ND	2
4 th Fl.-M	77.1	25.5	636	ND	2
4 th Fl.-Z	76.8	24.7	634	ND	1
4 th Fl.-O	76.6	24.6	608	ND	1
3 rd Fl.-A	76.5	25.5	616	ND	2
3 rd Fl.-M	77.6	24.3	641	ND	2
3 rd Fl.-Z	76.5	25.4	602	ND	3
1 st Fl.-O	76.9	26.0	619	ND	3
1 st Fl.-V	73.5	24.1	731	ND	2
1 st Fl.-M	74.8	24.6	585	ND	1
Basement Sal's Office	76.2	27.6	661	ND	3

°F = degrees Fahrenheit CO = Carbon monoxide

CO₂ = Carbon dioxide PPM = Parts Per Million

RH = Relative humidity ND = Non Detected

CITY_21MC100_003181381

