

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:



Attn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: 01231 / TOWN HOUSE / 51 HARRISON / INSIDE APTS

Customer ID: COMM56

Customer PO:

Received: 11/06/01 12:50 PM

EMSL Order: 030107554


EMSL Project ID:

Analysis Date: 11/6/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5μ - 5μ ≥ 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
623 030107554-0001	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
624 030107554-0002	1270.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
625 030107554-0003	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
626 030107554-0004	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
627 030107554-0005	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
628 030107554-0006	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
629 030107554-0007	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
630 030107554-0008	1260.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
631 030107554-0009	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
632 030107554-0010	1260.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
633 030107554-0011	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	

George William (18)


Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

1

CITY_21MC100_010315364

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL


Attn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465
Fax: (718) 904-9117 Phone: 718-792-2832
Project: 01231 / TOWN HOUSE / 51 HARRISON / INSIDE APTS

Customer ID: COMM56
Customer PO:
Received: 11/06/01 12:50 PM
EMSL Order: 030107554
EMSL Project ID:
Analysis Date: 11/6/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5μ - 5μ ≥ 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
634 030107554-0012	1210.00	0.0750	0	None Detected		0.0042	<13.33 <0.0042	
635 030107554-0013	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
636 030107554-0014	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
637 030107554-0015	1300.00	0.0625	0	Chrysotile	1 0	0.0047	16 0.0047	
638 030107554-0016	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
639 030107554-0017	1230.00	0.0750	0	None Detected		0.0042	<13.33 <0.0042	
640 030107554-0018	1230.00	0.0750	0	None Detected		0.0042	<13.33 <0.0042	

George William (18)



Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

2

CITY_21MC100_010315365

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSLAttn: Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Town House 51 Harrison Street, New York NY- Inside
Apts.

Customer ID: COMM56

Customer PO:

Received: 11/07/01 11:45 AM

EMSL Order: 030107604


EMSL Project ID:

Analysis Date: 11/7/2001

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
644 030107604-0001	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
645 030107604-0002	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
646 030107604-0003	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
647 030107604-0004	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
648 030107604-0005	1200.00	0.0750	1	None Detected		0.0043	<13.33 <0.0043	
649 030107604-0006	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
650 030107604-0007	1200.00	0.0750	1	None Detected		0.0043	<13.33 <0.0043	
651 030107604-0008	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	
652 030107604-0009	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
653 030107604-0010	1250.00	0.0625	0	None Detected		0.0049	<16.00 <0.0049	
654 030107604-0011	1260.00	0.0625	0	Chrysotile	1 0	0.0049	16 0.0049	

Jose Arriaga (12)


 Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #111506

TEMAHERA-1

1

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL

Attn: Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Town House 51 Harrison Street, New York NY- Inside
Apts.

Customer ID: COMM56

Customer PO:

Received: 11/07/01 11:45 AM

EMSL Order: 030107604


EMSL Project ID:

Analysis Date: 11/7/2001

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ - 5µ	≥ 5µ		(S/mm ²)	(S/cc)	
655 030107604-0012	1280.00	0.0625	0	None Detected			0.0048	<16.00	<0.0048	

Jose Arriaga (12)


Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1