

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSLAttn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228


EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
416 030107228-0001	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
417 030107228-0002	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
418 030107228-0003	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
419 030107228-0004	1340.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
420 030107228-0005	1320.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
421 030107228-0006	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
422 030107228-0007	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
423 030107228-0008	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
424 030107228-0009	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
425 030107228-0010	1280.00	0.0625	0	None Detected		0.0048	<16.00 <0.0048	
426 030107228-0011	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	

George William (20)


 Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSLAttn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228


EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5μ - 5μ ≥ 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
427 030107228-0012	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
428 030107228-0013	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
429 030107228-0014	1300.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
430 030107228-0015	1310.00	0.0625	0	None Detected		0.0047	<16.00 <0.0047	
431 030107228-0016	1380.00	0.0625	0	None Detected		0.0045	<16.00 <0.0045	
432 030107228-0017	1380.00	0.0625	0	None Detected		0.0045	<16.00 <0.0045	
433 030107228-0018	1380.00	0.0625	0	None Detected		0.0045	<16.00 <0.0045	
434 030107228-0019	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
435 030107228-0020	1360.00	0.0625	0	None Detected		0.0045	<16.00 <0.0045	
436 030107228-0021	1570.00	0.0500	0	None Detected		0.0049	<20.00 <0.0049	
437 030107228-0022	1570.00	0.0500	0	None Detected		0.0049	<20.00 <0.0049	

George William (20)


 Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/min. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State E-1 AP #11508

AHERA-1

2

CITY_21MC100_010315376

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSLAttn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228


EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ -5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
438 030107228-0023	1570.00	0.0500	0	None Detected		0.0049	<20.00 <0.0049	
439 030107228-0024	1550.00	0.0625	0	None Detected		0.0040	<16.00 <0.0040	
440 030107228-0025	1520.00	0.0625	0	None Detected		0.0041	<16.00 <0.0041	
441 030107228-0026	1450.00	0.0625	0	None Detected		0.0042	<16.00 <0.0042	
442 030107228-0027	1450.00	0.0625	0	None Detected		0.0042	<16.00 <0.0042	
443 030107228-0028	1450.00	0.0625	0	None Detected		0.0042	<16.00 <0.0042	
444 030107228-0029	1490.00	0.0625	0	None Detected		0.0041	<16.00 <0.0041	
445 030107228-0030	1460.00	0.0625	0	None Detected		0.0042	<16.00 <0.0042	
446 030107228-0031	1330.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
447 030107228-0032	1330.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
448 030107228-0033	1330.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	

George William (20)


Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEM AHERA-1

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900053 Email:



Attn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117

Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228

EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structure 0.5μ - 5μ ≥ 5μ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)		Notes
449 030107228-0034	1390.00	0.0625	1	None Detected			0.0044	<16.00	<0.0044	
450 030107228-0035	1370.00	0.0625	1	None Detected			0.0045	<16.00	<0.0045	
451 030107228-0036	1250.00	0.0625	3	None Detected			0.0049	<16.00	<0.0049	
452 030107228-0037	1250.00	0.0625	3	Chrysotile	0	1	0.0049	16	0.0049	
453 030107228-0038	1250.00	0.0625	1	None Detected			0.0049	<16.00	<0.0049	
454 030107228-0039	1300.00	0.0625	0	None Detected			0.0047	<16.00	<0.0047	
455 030107228-0040	1300.00	0.0625	3	Chrysotile	1	0	0.0047	16	0.0047	
456 030107228-0041	1320.00	0.0625	1	None Detected			0.0047	<16.00	<0.0047	
457 030107228-0042	1320.00	0.0625	0	None Detected			0.0047	<16.00	<0.0047	
458 030107228-0043	1320.00	0.0625	0	None Detected			0.0047	<16.00	<0.0047	
459 030107228-0044	1330.00	0.0625	0	None Detected			0.0046	<16.00	<0.0046	

George William (20)

Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSL

Attn: Victor Escalona
Commercial Lab Enterprise
270 Swinton Ave
Bronx, NY 10465

Fax: (718) 904-9117 Phone: 718-792-2832

Project: Building 1 80 North Moore Street NY NY

Customer ID: COMM56

Customer PO:

Received: 10/31/01 1:26 PM

EMSL Order: 030107228


EMSL Project ID:

Analysis Date: 10/31/01

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5 μ - 5 μ $\geq$ 5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
460 030107228-0045	1330.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
461 030107228-0046	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
462 030107228-0047	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
463 030107228-0048	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
464 030107228-0049	1350.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	
465 030107228-0050	1340.00	0.0625	0	None Detected		0.0046	<16.00 <0.0046	

George William (20)



Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11505

TEM AHERA-1

5

CITY_21MC100_010315379

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, November 02, 2001

Ref Number: LI0116584

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ³)	(S/cc)
469	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
470	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
471	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
472	1390.00	None Detected		0	0.0635	0.0044	<15.75	<0.0044
473	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
474	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Earl Tracey

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

1

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11459, CA ELAP 2339, CT PLI-0245

CITY_21MC100_010315380

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, November 02, 2001


Ref Number: LI0116584

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
475	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
476	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
477	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
478	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
479	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
480	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045


Earl Tracey

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

2



Filed for NVLAP PLM/TEM #101048-10, NY FLAP 11469, CA FLAP 2339, CT PL 0249

CITY_21MC100_010315381

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, November 02, 2001


Ref Number: LI0116584

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
481	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
482	1370.00	None Detected		0	0.0635	0.0044	<15.75	<0.0044
483	1200.00	None Detected		0	0.0762	0.0042	<13.12	<0.0042
484	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
485	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
486	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042


Earl Tracey

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

3


 Approved for NVLAP PLM/TEM #101048-10, NY FLAP 11469, CA FLAP 2338, CL PPL-0-30

CITY_21MC100_010315382

EMSL Analytical, Inc.

208 Stonehenge Lane
 Carle Place, NY 11514
 Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
 270 Swinton Avenue
 Bronx, NY 10465

Friday, November 02, 2001

Ref Number: LI0116584

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ < 5μ	Non- Asbestos $\geq 5\mu$			(S/mm ²)	(S/cc)
487	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
488	1790.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
489	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043
490	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043
491	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043
492	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043

Earl Tracey

Analyst

Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #191048-10, NY LAP 11460, CA LAP 2354, CCFR-0249

CITY_21MC100_010315383

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Friday, November 02, 2001

Ref Number: LI0116584

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
493	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
494	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043
495	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043
496	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043
497	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043
498	1750.00	None Detected		0	0.0508	0.0043	<19.69	<0.0043

Earl Tracey

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

Accredited for NVLAP PLM/TEM #101048-10, NY E1AP 11469, CA E1AP 2339, CT PL10-119

CITY_21MC100_010315384

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, November 02, 2001


Ref Number: LI0116584

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	Non- Asbestos ≥ 5μ			(S/mm ²)	(S/cc)
499	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
500	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
501	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
502	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
503	1360.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
504	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Earl Tracey

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel.
This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL.
This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples
reported above. Quality control data (including 95% confidence limits, and laboratory and analysts' accuracy and precision) is available upon request.

6

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_010315385

EMSL Analytical, Inc.

208 Stonehinge Lane
 Carle Place, NY 11514
 Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
 270 Swinton Avenue
 Bronx, NY 10465

Friday, November 02, 2001


Ref Number: LI0116584

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
505	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
506	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
507	1360.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
508	1360.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
509	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
510	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Earl Tracey

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY FIAP 11469, CA FIAP 2359, CT FIH-0749

CITY_21MC100_010315386

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Friday, November 02, 2001


Ref Number: LI0116584

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	Non- Asbestos ≥ 5μ			(S/mm ²)	(S/cc)
511	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
512	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
513	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
514	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
515	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
516	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047

Earl Tracey

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

8

Submitted for NVLAP PLM/TEM #101048-10, NY LAP 11469, CA LAP 2330, CLPH 0242

CITY_21MC100_010315387

EMSL Analytical, Inc.

208 Stonehinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Friday, November 02, 2001


Ref Number: LI0116584

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
517	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
518	1280.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
519	0.00	None Detected		0	0.0635		<15.75	
520	0.00	None Detected		0	0.0635		<15.75	
521	0.00	None Detected		0	0.0635		<15.75	

Earl Tracey

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

9

Accredited for NVLAP PLM/TEM #101046-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_010315388