

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Thursday, October 25, 2001

Ref Number: LI0116238

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 01231 310 GREENWICH ST NY, NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
88	1360.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
98	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
38R	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
160	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
161	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
162	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042

Earl Tracey

Analyst


 Approved
Signatory

Disclaimers. This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

1

Accredited for NVLAP PLM/TEM #101049 10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_010317867

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Thursday, October 25, 2001

Ref Number: LI0116238


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 01231 310 GREENWICH ST NY, NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - $< 5\mu$	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
163	1460.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
164	1460.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
165	1650.00	None Detected		0	0.0508	0.0046	<19.69	<0.0046
166	1650.00	None Detected		0	0.0508	0.0046	<19.69	<0.0046
167	1650.00	None Detected		0	0.0508	0.0046	<19.69	<0.0046
168	1650.00	None Detected		0	0.0508	0.0046	<19.69	<0.0046

Earl Tracey

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048 10, NY E-LAP 11469, CA E-LAP 2339 CT PH 0249

CITY_21MC100_010317868

EMSL Analytical, Inc.

208 Stonehinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Thursday, October 25, 2001

Ref Number: LI0116238


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 01231 310 GREENWICH ST NY, NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
169	1650.00	None Detected		0	0.0508	0.0046	<19.69	<0.0046
170	1700.00	None Detected		0	0.0508	0.0045	<19.69	<0.0045
171	1700.00	None Detected		0	0.0508	0.0045	<19.69	<0.0045
172	1700.00	None Detected		0	0.0508	0.0045	<19.69	<0.0045
173	1700.00	None Detected		0	0.0508	0.0045	<19.69	<0.0045
174	1700.00	None Detected		0	0.0508	0.0045	<19.69	<0.0045

Earl Tracey

Analyst


 Approved
 Signatory

Disclaimers. This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

3

Accredited for NVLAP P11M/TE, N #101048-10, NY FLAP 11463, CA FLAP 2339, CT PH-0249

CITY_21MC100_010317869

EMSL Analytical, Inc.

208 Stonehinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251

Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Thursday, October 25, 2001

Ref Number: LI0116238


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 01231 310 GREENWICH ST NY, NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	Non- Asbestos $\geq 5\mu$			(S/mm ²)	(S/cc)
175	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
176	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
177	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
178	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
179	1340.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
180	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042

Earl Tracey

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY CLAP 11469, CA ELAP 2339, C1 PH-0249

CITY_21MC100_010317870

EMSL Analytical, Inc.

208 Stonehenge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Thursday, October 25, 2001

Ref Number: LI0116238

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 01231 310 GREENWICH ST NY, NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
181	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
182	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
183	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
184	1460.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
185	1250.00	None Detected		0	0.0762	0.0040	<13.12	<0.0040
186	1250.00	None Detected		0	0.0762	0.0040	<13.12	<0.0040

Earl Tracey

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0245

CITY_21MC100_010317871

EMSL Analytical, Inc.208 Stonehinge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Thursday, October 25, 2001


Ref Number: LI0116238

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: 01231 310 GREENWICH ST NY, NY**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
187	1250.00	None Detected		0	0.0762	0.0040	<13.12	<0.0040
188	1240.00	None Detected		0	0.0762	0.0041	<13.12	<0.0041
189	1240.00	None Detected		0	0.0762	0.0041	<13.12	<0.0041
190	1260.00	None Detected		0	0.0762	0.0040	<13.12	<0.0040
191	1260.00	None Detected		0	0.0762	0.0040	<13.12	<0.0040
192	1260.00	None Detected		0	0.0635	0.0048	<15.75	<0.0048

Daniel Clarke

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

6

Accredited for NVLAP PLM/TEM: #101048-10, NY ELAP 11469, CA ELAP 2539, CT PH-0249

CITY_21MC100_010317872

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Thursday, October 25, 2001

Ref Number: LI0116238

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 01231 310 GREENWICH ST NY, NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
193	1250.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
194	1240.00	None Detected		0	0.0635	0.0049	<15.75	<0.0049
195	1280.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
196	1280.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
197	1310.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
198	1200.00	None Detected		0	0.0762	0.0042	<13.12	<0.0042

Daniel Clarke

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

7

Accredited for NVLAP PLM/TEM #101048-10 NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_010317873


EMSL Analytical, Inc.

208 Stonehinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251

Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Thursday, October 25, 2001

Ref Number: LI0116238


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 01231 310 GREENWICH ST NY, NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ $< 5\mu$	$\geq 5\mu$	Non- Asbestos			(S/mm ²)	(S/cc)
199	1290.00	Chrysotile	1	0	0	0.0635	0.0047	15.75	0.0047
200	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
201	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
202	1260.00	None Detected			0	0.0635	0.0048	<15.75	<0.0048
203	1260.00	None Detected			0	0.0635	0.0048	<15.75	<0.0048
204	0.00	None Detected			0	0.0635		<15.75	

Daniel Clarke

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

8

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_010317874

EMSL Analytical, Inc.

208 Stonehinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Thursday, October 25, 2001

Ref Number: LI0116238

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 01231 310 GREENWICH ST NY, NY

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
205	0.00	None Detected		0	0.0000			
206	0.00	None Detected		0	0.0000			

Daniel Clarke

Analyst


 Approved
Signatory

Disclaimers. This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

9

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_010317875