

INDOOR AIR QUALITY ANALYSIS

Project: Newmark & Co. Real Estate, Inc.
100 Gold Street

CTSI Project #:NY-442-01 Date: October 25, 2001

LOCATION	TEMPERATURE (°F)	RELATIVE HUMIDITY (RH%)	CO ₂ (PPM)	CO (PPM)	TOTAL VOC'S	TOTAL PARTICULATE LEVELS
	Standard = 68-74°F	Standard = 30-50%	Standard = 1,000 PPM	Standard = 9.0 PPM	Standard = Varies per specific parameter	Standard= 0.015 mg/m ³
Outside	73.8	37.4	339	1.4	ND	0.400
6 th Fl. Section-A	75.5	43.7	602	1.3	ND	0.001
6 th Fl. Section-M	74.4	43.4	615	1.2	ND	0.001
6 th Fl. Section-Z	74.1	46.0	673	1.3	ND	0.02
6 th Fl. Section-O	72.2	45.4	558	1.3	ND	0.001
8 th Fl. Section-A	73.2	44.8	556	1.2	ND	0.002
8 th Fl. Section-M	73.5	44.5	676	1.2	ND	0.001
8 th Fl. Section-Z	73.7	46.3	711	1.2	ND	0.001
8 th Fl. Section-O	73.3	46.2	625	1.2	ND	0.001
7 th Fl. Section-A	74.8	41.5	580	1.2	ND	0.004
7 th Fl. Section-M	73.9	42.1	594	1.2	ND	0.005
7 th Fl. Section-Z	74.4	43.6	644	1.2	ND	0.003
7 th Fl. Section-O	74.3	43.5	631	1.2	ND	0.003
5 th Fl. Section-A	74.2	39.7	534	1.1	ND	0.004
5 th Fl. Section-M	74.2	38.9	539	1.1	ND	0.003
5 th Fl. Section-Z	72.8	43.3	587	1.2	ND	0.002
5 th Fl. Section-O	72.8	43.1	573	1.1	ND	0.003

°F = degrees Fahrenheit CO = Carbon monoxide CO₂ = Carbon dioxide PPM = Parts Per Million
RH = Relative humidity ND = Non Detected

CITY_21MC100_011227124

