



ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel: (718) 784-7490

Fax: (718) 784-4085

PCM ☒ TEM ☐

CHECK ONLY ONE BOX

CLIENT SCA

PROJECT NO. (ATHENICA FILE#) 01-0613

PURPOSE OF MONITORING AREA SAMPLING

CASSETTE SIZE 25 mm LOT# 419HKA

TYPE-OF-RESPIRATOR

AREAS OF ABATEMENT Entire 10th, 11th, 12th, 8th Fl

Background ☐ Pre-Abatement ☐ Durrings ☐ Finals ☒ Others (Explain)

(CHECK ONLY ONE BOX)

SITE Financial HS 11th M 100 Trinity

DATE 11/24/01

TECHNICIAN G. Lopez, J. Baroutsos

ROTOMETER# AES 108A BATCH# 01-11-083

PROJECT MANAGER B. Belows

TYPE-OF-REMOVAL Dust Control

SAMPLE ID#	LOCATION	TYPE *	PUMP	TIME		TOTAL MIN.	FLOW			VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
				IN	OUT		BEFORE	AFTER	AVERAGE			
1	10th Fl by Exit B	TEM		1146	1314	94	14	14	14	1316	06/100	<.01
2	10th Fl Corridor by Rm# 1001			1141	1315	94	14	14	14	1316	08/100	<.01
3	10th Fl in Rm# 1002 by 104			1142	1316	94	14	14	14	1316	05/100	<.01
4	10th Fl in Rm# 1024 Center			1144	1318	94	14	14	14	1316	03/100	<.01
5	↓ ↓ 102 Center			1145	1319	94	14	14	14	1316	04/100	<.01
6	10th Fl Corridor by Rm# 1007A			1146	1320	94	14	14	14	1316	6.8/100	<.01
7	10th Fl In Rm# 1006 South			1147	1322	94	14	14	14	1316	09/100	<.01
8	↓ ↓ North			1148	1322	94	14	14	14	1316	05/100	<.01
9	10th Fl In side Stairwell A			1151	1325	94	14	14	14	1316	08/100	<.01
10	9th Fl Inside Stairwell A B			1152	1326	94	14	14	14	1316	03/100	<.01
11	9th Fl Corridor by Rm# 902			1153	1327	94	14	14	14	1316	06/100	<.01
12	9th Fl in Rm# 902			1154	1328	94	14	14	14	1316	04/100	<.01

BGA - Background
PRE - Preabatement

IWA - Inside Work Area
OB - Outside Building

ICR - Inside Clean Room
NGAE - Negative Air Exhaust

OWA - Outside work area
OTH - Other

OFNL - Outside Finals
IFNL - Inside Finals

CHAIN OF CUSTODY RECORD

RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>11-24-01</u>	TIME: <u>20:00</u>
RECEIVED BY: <u>[Signature]</u>	DATE: <u>11/24/01</u>	TIME: <u>20:00</u>
ANALYST: <u>[Signature]</u>	DATE: <u>11/24/01</u>	TIME: <u>21:00</u>

LABORATORY ACCREDITATION:
NVLAP# 101955 ELAP# 10955 METHOD: NIOSH 7400

WHITE-FILE/LAB YELLOW-SENT/REPORT PINK-FIELD

CITY_21MC100_009193324



PCM ☒ TEM ☐
CHECK ONLY ONE BOX

CLIENT SCAPROJECT NO. (ATHENICA FILE#) 81-0613PURPOSE OF MONITORING AREA SAMPLINGCASSETTE SIZE 25 mm LOT# 419H4ATYPE-OF-RESPIRATOR AREAS OF 10th, 11th 12th FlABATEMENT Background ☐ Pre-Abatement ☐ Durrings ☐ Finals ☒ Others (Explain)

(CHECK ONLY ONE BOX)

SITE Financial HS M 100 TrinityDATE 11/24/01TECHNICIAN G. Lopez, J. GaronitoROTOMETER# AES. 108A BATCH# 01-11-083PROJECT MANAGER B. BeloxTYPE-OF-REMOVAL Dust Control

SAMPLE ID#	LOCATION	TYPE *	PUMP	TIME		TOTAL MIN.	FLOW			VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
				IN	OUT		BEFORE	AFTER	AVERAGE			
13	9th Fl in Rm # 904 Center	IFNL		1155	1329	94	14	14	14	1316	04/100	<.01
14	9th Fl Corridor by Rm #905			1156	1330	94	14	14	14	1316	10/100	<.01
15	9th Fl in Rm # 915			1157	1331	94	14	14	14	1316	06/100	<.01
16	933 South			1158	1332	94	14	14	14	1316	08/100	<.01
17	933 North			1159	1333	94	14	14	14	1316	09/100	<.01
18	9th Fl Corridor by Rm #921			1200	1334	94	14	14	14	1316	05/100	<.01
19	8th Fl in Rm # 801			1205	1339	94	14	14	14	1316	03/100	<.01
20	8th Fl Corridor by Elevators			1206	1340	94	14	14	14	1316	02/100	<.01
21	8th Fl in Kitchen Center			1207	1341	94	14	14	14	1316	04/100	<.01
22	8th Fl Cafeteria East			1208	1342	94	14	14	14	1316	02/100	<.01
23	8th Fl in Stairwell #4			1209	1343	94	14	14	14	1316	03/100	<.01
24	8th Fl Cafeteria South West			1210	1344	94	14	14	14	1316	1.5/100	<.01

BGA - Background
PRE - Preabatement

IWA - Inside Work Area
OB - Outside Building

ICR - Inside Clean Room
NGAE - Negative Air Exhaust

OWA - Outside work area
OTH - Other

OFNL - Outside Finals
IFNL - Inside Finals

CHAIN OF CUSTODY RECORD

RELINQUISHED BY:	<u>John Soriano</u>	DATE:	<u>11/24/01</u>	TIME:	<u>20:00</u>
RECEIVED BY:	<u>[Signature]</u>	DATE:	<u>11/24/01</u>	TIME:	<u>20:00</u>
ANALYST:	<u>[Signature]</u>	DATE:	<u>11/24/01</u>	TIME:	<u>21:00</u>
LABORATORY ACCREDITATION:					
NVLAP# 101958 ELAP# 10955 METHOD: NIOSH 7400					

WHITE-FILE/LAB YELLOW-CLIENT/REPORT PINK-FIELD

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel: (718) 784-7480

Fax: (718) 784-4085

 PCM ☒ TEM ☐
 CHECK ONLY ONE BOX
CLIENT SCAPROJECT NO. (ATHENICA FILE#) 01-0613PURPOSE OF MONITORING AREA SAMPLINGCASSETTE SIZE 25 mm LOT# 419HKATYPE-OF-RESPIRATOR AREAS OF ABATEMENT Entire 7th and 6th fl A.
 Background ☐ Pre-Abatement ☐ Durrings ☐ Finals ☒ Others (Explain)

(CHECK ONLY ONE BOX)

SITE Financial HS MDATE 11/24/01TECHNICIAN G Lopez, J GarroteasROTOMETER# ACS 108A BATCH# 01-11-082PROJECT MANAGER B. BellasTYPE-OF-REMOVAL Post Control

SAMPLE ID#	LOCATION	TYPE *	PUMP	TIME		TOTAL MIN.	FLOW			VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
				IN	OUT		BEFORE	AFTER	AVERAGE			
25	FFNL	FFNL									00/100	
26	FFNL										00/100	
27	FFNL										00/100	
28	7th A Corridor by Bay B			16:05	17:35	90	14	14	14	1260	02/100	<.01
29	7th A Corridor by Bay B			16:06	17:36	90	14	14	14	1260	04/100	<.01
30	In Rm # 702 Center			16:07	17:37	90	14	14	14	1260	09/100	<.01
31	# 703 Center			16:08	17:38	90	14	14	14	1260	07/100	<.01
32	Corridor by Exit B			16:09	17:39	90	14	14	14	1260	03/100	<.01
33	In Rm # 706 Center			16:10	17:40	90	14	14	14	1260	08/100	<.01
34	# 705 Center			16:11	17:41	90	14	14	14	1260	06/100	<.01
35	# 704 Center			16:12	17:42	90	14	14	14	1260	04/100	<.01
36	6th fl. In Stairwell A			16:13	17:44	90	14	14	14	1260	04/100	<.01

BGA - Background
PRE - PreabatementIWA - Inside Work Area
OB - Outside BuildingICR - Inside Clean Room
NGAE - Negative Air ExhaustOWA - Outside work area
OTH - OtherOFNL - Outside Finals
IFNL - Inside Finals

CHAIN OF CUSTODY RECORD

RELINQUISHED BY: <u>Dorothy J. [Signature]</u>	DATE: <u>11/24/01</u>	TIME: <u>20:00</u>
RECEIVED BY: <u>[Signature]</u>	DATE: <u>11/24/01</u>	TIME: <u>20:00</u>
ANALYST: <u>[Signature]</u>	DATE: <u>11/24/01</u>	TIME: <u>20:45</u>

LABORATORY ACCREDITATION:

NVLAP# 101958 ELAP# 10855 METHOD: NIOSH 7400

WHITE-FILE/LAB YELLOW-SENT/REPORT PINK-FIELD

CITY_21MC100_009193326

NYC-WTC_000195804

01/23/2002 14:07 FAX 718 784 4085

01/05



PCM ☒ TEM
CHECK ONLY ONE BOX

ABATEMENT

Background ☐ Pre-Abatement ☐ Durings ☐ Finals ☒ Others (Explain) ☐

(CHECK ONLY ONE BOX)

TYPE-OF-REMOVAL	Dust Control
-----------------	--------------

[illegible]

OFNL Outside Finals
IFNL - Inside Finals

RELINQUISHED BY: <i>John [Signature]</i>	DATE: 11-24-01	TIME: 20:00
RECEIVED BY: <i>[Signature]</i>	DATE: 11/24/01	TIME: 20:00
ANALYST: <i>[Signature]</i>	DATE: 11/24/01	TIME: 20:45
LABORATORY ACCREDITATION:		
NVLAP# 101958	ELAP# 10955	METHOD: NIOSH 7400

WHITE-FILE/LAB YELLOW-CLIENT/REPORT PINK-FIELD