

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date
RJ Lee Group Job No.

2/7/2003
LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Chrysotile	Structures Amphibole	Concentration (s/mm ²)	(s/cc)	Analytical Sensitivity (s/mm ²)	(s/cc)
5148901	1/31/03	23	A	Field Blank	385	0	0.094	0	0	<10.67	---	10.67	---
5148902	1/31/03	23	D	Field Blank	385	0	0.094	0	0	<10.67	---	10.67	---
5148903	1/31/03	23	L	Field Blank	385	0	0.094	0	0	<10.67	---	10.67	---
5151268	1/31/03	24	H	North	385	2156.5	0.037	0	0	<26.67	<0.005	26.67	0.005
5151269	1/31/03	24	A	NorthWest	385	2189.75	0.037	0	0	<26.67	<0.005	26.67	0.005
5151270	1/31/03	24	G	North	385	2116.8	0.037	0	0	<26.67	<0.005	26.67	0.005
5151271	1/31/03	24	B	North	385	2337.07	0.037	0	0	<26.67	<0.004	26.67	0.004
5151272	1/31/03	24	D	North	385	2053.1	0.047	0	0	<21.34	<0.004	21.34	0.004
5151273	1/31/03	24	D	Field Blank	385	0	0.094	0	0	<10.67	---	10.67	---
5151274	1/31/03	24	A	Field Blank	385	0	0.094	0	0	<10.67	---	10.67	---
5151275	1/31/03	24	H	Field Blank	385	0	0.094	0	0	<10.67	---	10.67	---
5151281	1/31/03	23	A	NorthWest	385	1040.72	0.075	1	0	13.34	0.005	13.34	0.005
5151282	1/31/03	23	D	North	385	1908.9	0.047	0	0	<21.34	<0.004	21.34	0.004
5151283	1/31/03	23	L	NorthEast	385	2025	0.047	1	0	21.34	0.004	21.34	0.004
5151284	1/31/03	23	L	NorthEast	385	2034.63	0.047	0	0	<21.34	<0.004	21.34	0.004
5151285	1/31/03	23	A	NorthWest	385	1925	0.047	5	0	106.69	0.021	21.34	0.004

Notes:

1. Volumes provided by field personnel were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity.
3. Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
4. Abbreviations: NA - Not Analyzed
5. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

CITY_DEP_WORBY_CANNATA_SUBP_000037492