

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date
RJ Lee Group Job No.

4/22/2003
LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures Chrysotile Amphibole	Concentration (s/mm ²) (s/cc)	Analytical Sensitivity (s/mm ²) (s/cc)
5167638	4/16/03	0	AA	Field Blank	385	0	0.087	0 0	<11.54 ---	11.54 ---
5167639	4/16/03	0	AA	Field Blank	385	0	0.087	0 0	<11.54 ---	11.54 ---
5167640	4/16/03	0	AA	Field Blank	385	0	0.087	0 0	<11.54 ---	11.54 ---

Notes:

- Volumes provided by field personnel were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity.
- Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
- Abbreviations: NA - Not Analyzed
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

Page 1

CITY_DEP_WORBY_CANNATA_SUBP_000037500

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date
RJ Lee Group Job No.

4/22/2003
LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration		Analytical Sensitivity	
								Chrysotile	Amphibole	(s/mm ²)	(s/cc)	(s/mm ²)	(s/cc)
5167631	4/16/03	10	C	North	385	1800	0.043	0	0	<23.09	<0.005	23.09	0.005
5167632	4/16/03	10	D	NorthEast	385	1800	0.043	0	0	<23.09	<0.005	23.09	0.005

Notes:

- Volumes provided by field personnel were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity.
- Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
- Abbreviations: NA - Not Analyzed
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

Page 2

CITY_DEP_WORBY_CANNATA_SUBP_000037501

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date
RJ Lee Group Job No.

4/22/2003
LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration		Analytical Sensitivity	
								Chrysotile	Amphibole	(s/mm ²)	(s/cc)	(s/mm ²)	(s/cc)
5167629	4/16/03	12	A	NorthWest	385	1800	0.043	0	0	<23.09	<0.005	23.09	0.005
5167630	4/16/03	12	D	NorthEast	385	1800	0.043	1	0	23.09	0.005	23.09	0.005

Notes:

1. Volumes provided by field personnel were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity.
3. Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
4. Abbreviations: NA - Not Analyzed
5. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

Page 3

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date 4/22/2003
RJ Lee Group Job No. LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration		Analytical Sensitivity	
								Chrysotile	Amphibole	(s/mm ²)	(s/cc)	(s/mm ²)	(s/cc)
5167627	4/16/03	14	C	North	385	1815	0.043	0	0	<23.09	<0.005	23.09	0.005
5167628	4/16/03	14	E	NorthEast	385	1800	0.043	0	0	<23.09	<0.005	23.09	0.005

Notes:

- Volumes provided by field personnel were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity.
- Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
- Abbreviations: NA - Not Analyzed
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

Page 4

CITY_DEP_WORBY_CANNATA_SUBP_000037503

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date 4/22/2003
RJ Lee Group Job No. LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration		Analytical Sensitivity	
								Chrysotile	Amphibole	(s/mm ²)	(s/cc)	(s/mm ²)	(s/cc)
5167625	4/16/03	15	A	North West	385	1835	0.043	0	0	<23.09	<0.005	23.09	0.005
5167626	4/16/03	15	E	North East	385	1835	0.043	0	0	<23.09	<0.005	23.09	0.005

Notes:

1. Volumes provided by field personnel were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity.
3. Accreditation: PADEP -- 02-396; NYLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
4. Abbreviations: NA - Not Analyzed
5. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date 4/22/2003
RJ Lee Group Job No. LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures Chrysotile Amphibole	Concentration (s/mm ²) (s/cc)	Analytical Sensitivity (s/mm ²) (s/cc)
5167623	4/16/03	17	B	NorthWest	385	1915	0.043	0 0	<23.09 <0.005	23.09 0.005
5167624	4/16/03	17	C	North	385	1905	0.043	0 0	<23.09 <0.005	23.09 0.005

Notes:

- Volumes provided by field personnel were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity.
- Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
- Abbreviations: NA - Not Analyzed
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

Page 6

CITY_DEP_WORBY_CANNATA_SUBP_000037505

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date
RJ Lee Group Job No.

4/22/2003
LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures Chrysotile Amphibole	Concentration (s/mm ²) (s/cc)	Analytical Sensitivity (s/mm ²) (s/cc)
5167620	4/16/03	18	A	North West	385	2075	0.043	0 0	<23.09 <0.004	23.09 0.004
5167621	4/16/03	18	C	North	385	2025	0.043	1 0	23.09 0.004	23.09 0.004

Notes:

- Volumes provided by field personnel were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity.
- Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIIHA -- 100364/460; NYELAP -- 10884
- Abbreviations: NA - Not Analyzed
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

Page 7

CITY_DEP_WORBY_CANNATA_SUBP_000037506

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date 4/22/2003
RJ Lee Group Job No. LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration		Analytical Sensitivity	
								Chrysotile	Amphibole	(s/mm ²)	(s/cc)	(s/mm ²)	(s/cc)
5167635	4/16/03	8	B	NorthWest	385	2040	0.043	0	0	<23.09	<0.004	23.09	0.004
5167636	4/16/03	8	D	North	385	2040	0.043	0	0	<23.09	<0.004	23.09	0.004
5167637	4/16/03	8	H	NorthEast	385	2040	0.043	0	0	<23.09	<0.004	23.09	0.004

Notes:

- 1. Volumes provided by field personnel were used to calculate analytical results and sensitivities.
- 2. "<" indicates results less than analytical sensitivity.
- 3. Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
- 4. Abbreviations: NA - Not Analyzed
- 5. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

CITY_DEP_WORBY_CANNATA_SUBP_000037507

RJ Lee Group, Inc.

350 Hochberg Road · Monroeville, PA 15146
Voice 724-325-1776 · Fax 724-733-1799

Laboratory Report

130 Liberty Building
Aggressive Air Testing
Air Sample Results

Report Date 4/22/2003
RJ Lee Group Job No. LSH204785
Deutsche Bank Buildings

TEM Air Sample Analysis Results
Method: AIHERA method -- 40 CFR, Part 763

RJLG Sample Number	Date Collected	Floor	Grid	Sample Description	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration		Analytical Sensitivity	
								Chrysotile	Amphibole	(s/mm ²)	(s/cc)	(s/mm ²)	(s/cc)
5167633	4/16/03	9	A	North West	385	2422	0.035	0	0	<28.86	<0.005	28.86	0.005
5167634	4/16/03	9	F	North East	385	2359	0.035	0	0	<28.86	<0.005	28.86	0.005

Notes:

- Volumes provided by field personnel were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity.
- Accreditation: PADEP -- 02-396; NVLAP -- 101208; AIHA -- 100364/460; NYELAP -- 10884
- Abbreviations: NA - Not Analyzed
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Authorized Signature

Manager, TEM Department

4/22/03

Page 9

CITY_DEP_WORBY_CANNATA_SUBP_000037508