

EMSL Analytical, Inc.

1056 Stelton Road, Piscataway, NJ 08854

Phone: 732-881-0550 Fax: 732-981-0551 Email:

EMSL

Attn: George Russell
Environmental Monitoring & Consulting
(EM & CA)
P.O. Box 872
Somerville, NJ 08876

Fax: (732) 249-3384

Phone: 732-249-3005

Project: 71 Broadway

Customer ID: EMCA50

Customer PO:

Received: 01/24/02 5:40 PM


EMSL Order: 050200343

EMSL Project ID:

Analysis Date: 1/29/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
7123001 0200343-0001	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
7123002 0200343-0002	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
23003 050200343-0003	1800.00	0.0500	1	None Detected		0.0043	<20.00 <0.0043	
23004 0200343-0004	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
7123005 0200343-0005	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
7123006 050200343-0006	1800.00	0.0500	1	None Detected		0.0043	<20.00 <0.0043	
23007 050200343-0007	1800.00	0.0500	1	None Detected		0.0043	<20.00 <0.0043	
23008 0200343-0008	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
7123009 0200343-0009	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
23010 050200343-0010	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	



Drew Hodgen (10)


Adrian Arav
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analytical accuracy and precision) is available upon request.

Analysis performed by EMSL Piscataway (NY State ELAP #11423, NVLAP #101048-2, Connecticut DOH PH-0286 Approved Env. Lab)

TEMAHERA-1

1