

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 323-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 8/17/2004
Sample Receipt Date: 8/16/2004
RJ Lee Group Job No.: ATH306366-1004
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
		Start	Stop								(S/mm ²)	(S/cc)
5228196.HT	Field	8/14/2004		99	Not	(NorthWest) - Washington and Cedar	385	0.000	0.08973	0	< 11.1	N/A
	Blank	8/14/2004			Acquired						11.1	N/A
5228198.HT	Area	8/14/2004		99	Not	(SouthEast) - Greenwich and Albany	385	1684.00	0.05384	0	< 18.6	< 0.004
		8/14/2004			Acquired						18.6	0.004
5228197.HT	Area	8/14/2004		99	Not	(SouthWest) - Washington and Albany	385	1676.00	0.05384	0	< 18.6	< 0.004
		8/14/2004			Acquired						18.6	0.004
5228199.HT	Area	8/14/2004		99	N/A	(East) - Greenwich	385	1684.00	0.05384	0	< 18.6	< 0.004
		8/14/2004									18.6	0.004
5228200.HT	Area	8/14/2004		99	Not	(NorthWest) - Washington and Cedar	385	1684.00	0.05384	0	< 18.6	< 0.004
		8/14/2004			Acquired						18.6	0.004

Authorized Signature:



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable; Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3