

7/31

RJ LeeGroup, Inc.

 350 Hochberg Road, Monroeville, PA 15146
 Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

 RJ Lee Group, Inc.
 350 Hochberg Road
 Monroeville, PA 15146
 USA

 Report Date: 8/3/2004
 Sample Receipt Date: 8/2/2004
 RJ Lee Group Job No: ATH306366-946
 Samples Received: 5
 Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity		
										(S/mm ³)	(S/cc)	
5227174.HT	Field Blank	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0	0	< 11.4 11.4	N/A N/A
5227176.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1772.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227175.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1764.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227177.HT	Area	7/31/2004 7/31/2004	99	N/A	(East) - Greenwich	385	1772.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227178.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1776.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005

Authorized Signature:



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3