

Jul 02 04 05:27p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 7/1/2004 Time: 1:20:12 PM

Page 2 of 4 P. 12
6/28

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/30/2004
Sample Receipt Date: 6/29/2004
RJ Lee Group Job No: ATH306366-816
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ²)	(S/cc)
5220277 HT	Area	6/28/2004 6/28/2004	0	Z	(South) - Decon Exit	385	1888.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220278 HT	Area	6/28/2004 6/28/2004	0	FF	(South) - Shanty Area	385	1888.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220279 HT	Area	6/28/2004 6/28/2004	0	Y	(South) - Decon Entrance	385	1884.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220280 HT	Area	6/28/2004 6/28/2004	0	X	(South) - Ramp	385	1888.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220281 HT	Field Blank	6/28/2004 6/28/2004	0	X	(South) - Ramp	385	0.000	0.08650	0 0	< 11.6 11.6	N/A N/A
5220282 HT	Field Blank	6/28/2004 6/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08650	0 0	< 11.6 11.6	N/A N/A
5220283 HT	Area	6/28/2004 6/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1888.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220284 HT	Area	6/28/2004 6/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1892.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220286 HT	Area	6/28/2004 6/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1912.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220285 HT	Area	6/28/2004 6/28/2004	99	N/A	(East) - Greenwich	385	1908.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 02 04 05:28p IBM USER
 From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/7/2004 Time: 1:20:12 PM
 732 6018

P. 13

RJ Lee Group, Inc.


Laboratory Report (cont.)

RJ Lee Group Job No. ATH306366-816
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/30/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5220287 HT	Area	6/28/2004 6/28/2004	1	K	(NorthWest) - Cedar Decon	385	1912.00	0.04325	0 0	< 23.1 23.1	< 0.305 0.305

Authorized Signature: _____


 /s/b
 Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "----" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Moonreville, PA (NVLAP #101208-0, NY ELAP #10844) facility
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

CITY_DEP_WORBY_CANNATA_SUBP_000034342