


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 12:00LOCATION PS 234 M DATE 2/28/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
7:50AM. Outside Main Entrance						13	
7:50AM Inside By Main Desk						10	
NW Corner Outside		37.0	30.1	446	0	26	0
NE Corner Outside		37.5	30.5	450	0	28	0
SE Corner Outside		37.9	31.1	455	0	30	0
SW Corner Outside		37.3	31.9	459	0	27	0
Outside Playground		36.9	32.3	463	0	25	0
Outside Courtyard		36.5	32.5	468	0	20	0
Outside North Side		36.3	33.0	473	0	18	0
Outside Main Entrance		36.9	32.8	484	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/28/02


CITY_21MC100_003056911

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6TIME 12:20LOCATION PS 234 MDATE 2/28/02PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Main Foyer.		74.6	10.9	631	0	10	0
Main Desk		72.0	10.4	594	0	12	0
Hall by Gym		70.8	9.8	599	0	10	0
Gym.	26	72.1	10.6	609	0	11	0
Cafeteria		76.5	11.7	635	0	8	0
Hall by Exit 1		71.4	11.2	626	0	10	0
108	1	71.8	11.4	718	0	12	0
Hall by Elevator		71.6	10.5	624	0	12	0
114 (Hall)		71.4	11.7	778	0	14	0
116	1	73.2	14.4	777	0	13	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/28/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6TIME 12:40LOCATION PS 234 M DATE 2/28/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
118	20	73.8	17.3	965	0	18	0
120	30	74.6	17.3	924	0	16	0
122	21	72.5	15.7	951	0	18	0
Hall by Stair 3	—	74.0	17.0	846	0	12	0
Stair 3	—	71.5	17.5	765	0	13	0
222	—	71.9	22.6	957	0	14	0
220	—	76.1	25.5	1100	0	14	0
218	—	76.2	18.7	1190	0	14	0
216	—	75.8	17.9	1205	0	16	0
214 (Hall)		75.2	19.2	1079	0	14	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: _____

CITY_21MC100_003056913

ATC ASSOCIATES, INC.

Page 4 of 6

TIME 1300

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS 234 MDATE 2/28/02PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
229	26	76.3	24.8	1325	10243 0	10	0
227 (Hall)	—	75.0	15.9	888	0	13	0
210 (Hall)	—	74.6	13.5	788	0	12	0
Hall by Stair-1	—	74.5	13.2	780	0	12	0
225 (door closed)	19	74.9	23.3	1681	0	19	0
223	23	78.7	17.1	1081	0	14	0
219 (door closed)	22	77.3	23.4	1509	0	12	0
Hall by Elevator	—	77.3	14.7	858	0	12	0
207	—	77.8	16.4	935	0	10	0
207 (Hall)	—	77.7	15.4	967	0	11	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

2/28/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 13:35LOCATION PS 234 MDATE 2/28/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
215 (Hall)		76.9	16.8	1181	0	16	0
211	27	76.8	20.3	1301	0	20	0
Hall by Stair 2	—	76.0	17.3	1204	0	14	0
201	4	75.3	18.6	1369	0	15	0
202	2	75.0	18.3	1377	0	15	0
3rd FL. Stair #2	—	72.9	20.3	1640	0	18	0
301	6	73.8	20.7	1690	0	15	0
302	—	73.6	19.9	1580	0	14	0
305 (Door open)	—	73.6	24.6	2081	0	18	0
304	4	74.9	22.1	1489	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/28/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 13:55LOCATION PS 234 M DATE 2/28/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
311	-	74.4	23.3	1960	0	9	0
315	-	73.8	19.6	1453	0	13	0
308	1	73.4	21.2	1506	0	16	0
319	-	73.3	21.3	1781	0	16	0
Hall 310	-	74.4	17.4	1238	0	10	0
323	-	73.2	17.1	1250	0	11	0
310	3	74.1	15.2	938	0	9	0
329 (Hall)	-	74.7	18.2	1270	0	14	0
316	1	74.7	24.4	1590	0	20	0
320	1	73.2	23.1	1640	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/28/02