NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

BATCH NO.

BULK SAMPLE DATA AND CHAIN OF CUSTODY FORM

PROJECT INFORMATION

1. Client: NYC - BOE	2. Project Nam AHERA REINSPECTION	3. Project # 14584-0823	4. Project Manager: ANDREAS ANDREOU
	2a. Project Address:292 Greenwich street, New York, NY 10007		4a. Investigator:Yiannis Efstathiou

5. Date: 2/5/02	6. Building Name:PS 234M	8. Turnaround Time: ☐ STAT ☐ 24 HRS ☐ 72 HRS ☐ OTHER ☐ 6 HRS ☐ 48 HOURS ☐ NORMAL	9. Comments (Field): Analyzed all them for fiberglass
	7. Sampling Areas:		10. Time in / Time out:

H.A.#	SAMPLE ID NUMBER	MATERIAL DESCRIPTION	LOCATION	FLOOR NUMBER	RESULTS
	PS234M-2/5/02-Fiberglass-01	Settled Dust	Cafeteria		NONE DETECTED
	PS234M-2/5/02-Fiberglass-02	Settled Dust	1st floor hallway		↓
	PS234M-2/5/02-Fiberglass-03	Settled Dust	Auditorium		↓
	PS234M-2/5/02-Fiberglass-04	Settled Dust	Classroom #311 (Facing south)		TRACES OF FIBERGLASS FIBERS DETECTED
	PS234M-2/5/02-Fiberglass-05	Settled Dust	Classroom #211 (Facing south)		2% FIBERGLASS FIBERS DETECTED
	PS234M-2/5/02-Fiberglass-06	Settled Dust	Classroom #302 (Facing east)		NONE DETECTED

CHAIN OF CUSTODY

17. Relinquished By:	18. Date:	19. Time:	20. Received By:	21. Date:	22. Time:
Yiannis Efstathiou	2/5/02		GA	2/5/02	5:00

23. Method of Submittal:	
FIELD	
WALK IN	
US MAIL	
FED-X	
OTHER	

LAB INFORMATION

24. Name and Signature:	25. Date:	26. Time:
24a. Analyzed By: GA	2/5/02	9:00PM
24b. Analyzed By:		
24c. QC By:		

27. Comments (Lab):

Filename: P:\USERS\DATA\WP96\WP\FORMS\NY-13.XLS

Form NY-13

CITY_21MC100_006752129

NYC-WTC_000196538