



600 West Cummings Park, Suite 6500
 Woburn, Massachusetts 01801-6350
 www.atc-enviro.com
 781.932.9400
 Fax 781.932.6211

February 8, 2002

Mr. Bernard P. Orlan
 New York City Board of Education
 Director, Environmental Health & Safety Unit
 28-11 Queens Plaza North
 Long Island City, NY 11101

Re: Limited settled dust bulk sampling for fiberglass at P.S. 234M

Dear Mr. Orlan:

At your request, ATC Associates, Inc. representative Mr. Yiannis Efstathiou visited P.S. 234M located at 292 Greenwich Street, New York, NY 10007 on February 7th, 2002. The purpose of the site visit was to perform a limited settled dust bulk sampling to be analyzed for fiberglass fiber content only in classroom #211 after a custodial cleanup was performed.

This bulk sampling was a follow up testing in response to the February 5th bulk sampling where one sample collected from classroom #211 was found to contain more than 1% fiberglass fibers. Bulk sampling was performed after a custodial clean up of classroom #211 was completed.

A total of three (3) settled dust bulk samples were collected from classroom 3211 and were analyzed utilizing Polarized Light Microscopy (PLM).

Analytical results indicated that none of the three (3) collected settled dust bulk samples contain fiberglass fibers.


The settled dust bulk sampling performed was limited to testing for fiberglass in classroom #211 after a custodial clean up was completed in response to the recommendations of the February 5th bulk sampling findings.

Attached please find the following:

- Settled dust bulk sample chain of custody form and laboratory results
- Laboratory and personnel certificates

If you have any questions or require additional information regarding this limited settled dust bulk sampling, please do not hesitate to contact me at (212) 353-8280 extension #261.

Sincerely,

A handwritten signature in black ink, appearing to read "A. Andreou", with a horizontal line drawn through the middle of the signature.

Andreas C. Andreou
Senior Project Manager

Cc: Mr. T. Fusillo (ENVIRON Corp.)
Ms. C. Procter (UFT)
Mr. C. D'Andrea (NYC-DOH)