

ATC Associates

104 East 25 Street, New York, NY 10010

Phone (212) 353-8280

Fax (212) 353-8306



Attn: Yiannis Efstathiou

ATC Associates Inc

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 9/14/02

6 00 00 PM

ATC Group #: 8837

Analysis Date: 9/15/02

Project: NYC-DOE PS 124M ATC Project # 14584-0877

40 Division Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm ²)	(S/cc)	
01 8837 -1	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
02 8837 -2	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
03 8837 -3	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
04 8837 -4	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
05 8837 -5	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
06 8837 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
07 8837 -7	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by

MICHAEL A. GORYCKI, Ph.D.

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Yiannis Efstathiou

ATC Associates Inc

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Project: NYC-DOE PS 124M ATC Project # 14584-0877

40 Division Street, New York, NY

Received: 9/14/02

6 00 00 PM

ATC Group #: 8837


Analysis Date: 9/15/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5µ		Analytical	Asbestos	Notes
							Sensitivity (S/cc)	Concentration (S/mm ²) (S/cc)	
08 8837 -8	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044	
09 8837 -9	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044	
10 8837 -10	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044	
11 8837 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24 <0.0045	
12 8837 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24 <0.0045	
13 8837 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24 <0.0045	
14 8837 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24 <0.0045	
15 8837 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24 <0.0045	


ROMAN PEYSAKHOV

Analyzed by



MICHAEL A. GORYCKI, Ph.D.

Approved by



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879