

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-23-02

CLIENT: NYC BOE

PROJECT ADDRESS: 122 Henry Street
NY, NY 10002

PROJECT NO: 41617-0884

SAMPLED BY: H. Antonyan

SAMPLE DATE: 08-23-02
DATE RECEIVED: 08-23-02
DATE ANALYZED: 08-23-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
01	9951	3rd Floor Hallway by Rm 313 Floor	<9.0	9.0
02	9951	Rm 322 Floor	<9.0	9.0
03	9951	Rm 317 Floor	<9.0	9.0
04	9951	Rm 213 Window Sill	<4.1	4.1
05	9951	Rm 224 Floor	<9.0	9.0
06	9951	2nd Floor Hallway by Rm 222 Floor	<9.0	9.0
07	9951	1st Floor Hallway by Rm 113 Floor	<9.0	9.0
08	9951	Rm 113 Window Sill	<4.1	4.1
09	9951	Rm 118 Floor	<9.0	9.0
10	9951	Auditorium Floor	<9.0	9.0
11	9951	Cafeteria Floor	<9.0	9.0
12	9951	Main Lobby Floor	<9.0	9.0
13	9951	Basement Hallway by Rm B5 Floor	<9.0	9.0
14	9951	Rm B7 Window Sill	<4.1	4.1

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

15	9951	Rm B3 Floor	<9.0	9.0
16	9951	Blank	<9.0 µg	9.0 µg
17	9951	Blank	<9.0 µg	9.0 µg

NOTE 1

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft²,
Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: TL

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).