NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 09-05-02

CLIENT: NYC BOE

PROJECT ADDRESS: PS 42M / 71 Hester Street
NY, NY 10002

SAMPLED BY: M. Nakhumovich

SAMPLE DATE: 09-03-02
DATE RECEIVED: 09-04-02
DATE ANALYZED: 09-04-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
01	9978	1st Floor Lobby Floor	<9.0	9.0
02	9978	Cafeteria Floor	<9.0	9.0
03	9978	Auditorium Floor	<9.0	9.0
04	9978	Classroom 206 Window Sill	<4.5	4.5
05	9978	Classroom 309 Floor	<9.0	9.0
06	9978	1st Floor Hallway Floor	<9.0	9.0
07	9978	2nd Floor Hallway Floor	<9.0	9.0
08	9978	3rd Floor Hallway Floor	<9.0	9.0
09	9978	4th Floor Hallway Floor	<9.0	9.0
10	9978	5th Floor Hallway Floor	<9.0	9.0
11	9978	Blank	<9.0 µg	9.0 µg
12	9978	Blank	<9.0 µg	9.0 µg

NOTE 1
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3
Blank units are in µg

NYC-WTC_000196752

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC-WTC_000196753