

ATC Associates104 East 25th Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Received: 3/5/02

9:00:00 PM

ATC Group #: 6942

Analysis Date: 3/6/02

Project: H.S. Of Economics And Finance

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
03 6942 -1	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
04 6942 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 6942 -3	1818.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 6942 -4	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 6942 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
08 6942 -6	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
09 6942 -7	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 6942 -8	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003044285

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 3/5/02 9:00:00 PM
ATC Group #: 6942
Analysis Date: 3/6/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5μ-5	5μ		(S/mm ²)	(S/cc)	
11 6942 -9	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 6942 -10	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 6942 -11	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 6942 -12	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 6942 -13	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 6942 -14	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 6942 -15	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
18 6942 -16	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
19 6942 -17	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates, Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003044286