



104 East 25th St., 10th Floor
 New York, New York 10010
 www.atc-enviro.com
 212.353.8280
 Fax 212.353.8306

June 6, 2002

Mr. Bernard P. Orlan
 Director, Environmental Health & Safety
 New York City Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101-4008

Re: Air Sampling for Silica
High School of Economics and Finance (M833)
100 Trinity Place
New York, New York
ATC Project No. 15-19125-0291

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of the results of air sampling for silica-containing dust conducted on March 23 and 30, 2002, at the referenced school. The New York City Board of Education (BOE) requested this monitoring to evaluate possible contamination in the building.

Scope of Work

Each day, ATC collected three (3) samples for respirable dust using pre-weighed 37mm PVC filters connected to size-selective cyclones to remove the larger (non-respirable) particles prior to deposition on the filters. All of the samples were collected indoors. The samples (and one blank) were sent to PSC Analytical Services, Inc., an American Industrial Hygiene Association accredited laboratory in Reading, PA. Analysis for silica was performed by x-ray diffraction according to OSHA Method 142. A copy of the analytical report is attached.

Tenzin Namgyal and Wagdi Abdelshahid, Industrial Hygienists of ATC's New York City office, collected the samples consistent with generally accepted industrial hygiene practices. As with all such sampling, there were inherent limitations created by constraints of time, operational and work practice variability, variations in air contaminant concentrations and sampling and analytical accuracy. The results of the sampling represent conditions found on the date the samples were collected.

Results

Samples were obtained in the following locations: 1st floor Main Lobby, 5th floor by the elevator and 10th floor by Stair B.

The results of all of the samples were reported to be ***below the detection limit*** for silica (<10.0 micrograms per sample).

CITY_21MC100_003028860


Mr. Bernard P. Orlan
Air Sampling for Silica
H.S. for Economics & Finance

June 6, 2002
Page 2

ATC Project No. 15-19125-0291

It is our pleasure to provide these indoor air consultative services to the New York City Board of Education. If you have any questions about this report, please call (212) 353-8280, extension 212.

Sincerely,
ATC Associates, Inc.



Ronny D. Romero
Senior Project Manager



James R. Cohn, CIH, CSP
Regional Manager
Industrial Hygiene Division

Attachment