

Potable Water Re-sampling
H.S. of Economics & Finance
January 28, 2002

ATTACHMENT A
LABORATORY REPORT AND
CHAIN OF CUSTODY FORMS

CITY_21MC100_003028992

New York Environmental & Analytical Laboratories, Inc.

an independent full service testing & consulting firm

88 Harbor Road
Port Washington, NY 11050
Tel. (516) 944-9500 Fax. (516) 944-9507

CLIENT: ATC Associates, Inc.
104 East 25th Street, 10th Floor
New York, NY


REPORT #: 220241
PROJECT #: 012202LC

PROJECT: M833

SAMPLE DATE: 01/22/01
ANALYSIS DATE: 01/22/01
REPORT DATE: 01/22/01

ANALYTICAL REPORT
for
NON-METALS IN DRINKING WATER
(STANDARD METHODS 18TH EDITION)

SAMPLE NO	SAMPLE LOCATION	COLOR (Color Unit)
M833-1C	10th floor hallway	14
M833-2C	9th floor hallway	12
M833-3C	8th floor kitchen	8
M833-4C	8th floor cafeteria	22
M833-5C	6th floor hallway	28
M833-6C	3rd floor hallway	8
M833-7C	2nd floor hallway	13


Li Tsang
Laboratory Director

LT/lg;

New York Environmental & Analytical Laboratories, Inc.

an independent full service testing & consulting firm

88 Harbor Road
Port Washington, NY 11050
Tel. (516) 944-9500 Fax. (516) 944-9507

CLIENT: ATC Associates, Inc.
104 East 25th Street, 10th Floor
New York, NY

REPORT #: 220241
PROJECT #: 012202LC

SAMPLE DATE: 01/22/01


ANALYSIS DATE: 01/22/01

PROJECT: M833

REPORT DATE: 01/22/01

ANALYTICAL REPORT FOR METALS IN DRINKING WATER (STANDARD METHODS 18TH EDITION)

SAMPLE NO	Pb (mg/L)	Cu (mg/L)	Fe (mg/L)	Zn (mg/L)	Mn (mg/L)	Cd (mg/L)	Cr (mg/L)
M883-1F	----	----	0.12	----	----	----	----
M883-2F	----	----	0.11	----	----	----	----
M883-3F	----	----	0.13	----	----	----	----
M883-FB	----	----	<0.01	----	----	----	----



Li Tsang
Laboratory Director

LT/lg;