

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orian
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 1/30/02 9:15:00 PM

ATC Group #: 6517

Analysis Date: 1/31/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
Playground, Roof, 1st Floor Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm²)	(S/cc)	
1 6517-1	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
2 6517-2	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
3 6517-3	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
4 6517-4	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
5 6517-5	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
6 6517-6	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
7 6517-7	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
8 6517-8	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003047240

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 1/30/02 9:15:00 PM

ATC Group #: 6517

Analysis Date: 1/31/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
Playground, Roof, 1st Floor Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
9 6517-9	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
10 6517-10	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
11 6517-11	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
12 6517-12	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
13 6517-13	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
14 6517-14	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
15 6517-15	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
16 6517-16	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003047241