

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 5/9/02 9:00:00 PM
 ATC Group #: 7685
 Analysis Date: 5/10/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
 Playground, Roof All Floors Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
03 7685 -1	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
04 7685 -2	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
05 7685 -3	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
06 7685 -4	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
07 7685 -5	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
08 7685 -6	1968.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
09 7685 -7	1968.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 5/9/02 9:00:00 PM
ATC Group #: 7685
Analysis Date: 5/10/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
Playground, Roof All Floors Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
10 7685 -8	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
11 7685 -9	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
12 7685 -10	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
13 7685 -11	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
14 7685 -12	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
15 7685 -13	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
16 7685 -14	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
17 7685 -15	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
18 7685 -16	1960.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879