

ATC ASSOCIATES INC.

BATCH NO.

19653

BULK SAMPLE DATA AND CHAIN OF CUSTODY FORM

PROJECT INFORMATION

1. Client: NYC - BOE	2. Project Name: AHERA REINSPECTION	3. Project # 14584-0819	4. Project Manager: ANDREAS ANDREOU
2a. Project Address: 201 Warren street, New York, NY 10282			4a. Investigator: Yiannis Efstathiou
5. Date: <u>1/25/02</u>	6. Building Name: PS 89M	8. Turnaround Time: ☐ STAT ☐ 24 HRS ☐ 72 HRS ☐ OTHER ☐ 6 HRS ☐ 48 HOURS ☐ NORMAL	9. Comments (Field): Analyzed all them for fiberglass 10. Time in / Time out:

H.A.#	SAMPLE ID NUMBER	MATERIAL DESCRIPTION	LOCATION	FLOOR NUMBER	RESULTS
	PS89M-1/25/02- Fiberglass- 01	Settled Dust	2nd Floor hallway - south end		2 1/2 FIBERGLASS FIBERS
	PS89M-1/25/02- Fiberglass- 02	Settled Dust	Classroom # 202 south side ventilator		TR FIBERGLASS FIBERS
	PS89M-1/25/02- Fiberglass- 03	Settled Dust	Classroom # 226 north side ventilator		ND
	PS89M-1/25/02- Fiberglass- 04	Settled Dust	4th Floor hallway - south end		ND
	PS89M-1/25/02- Fiberglass- 05	Settled Dust	Classroom # 404 east side ventilator		ND

CHAIN OF CUSTODY

17. Relinquished By: <i>Yiannis Efstathiou</i>	18. Date:	19. Time:	20. Received By: <i>J. Achubor</i>	21. Date: <u>1/25/02</u>	22. Time: <u>5:15 pm</u>	23. Method of Submittal:
						FIELD
						WALK IN
						US MAIL
						FED-X
						OTHER

LAB INFORMATION

24. Name and Signature:	25. Date:	26. Time:	27. Comments (Lab):
24a. Analyzed By: <i>J. Achubor</i>	<u>1/25/02</u>	<u>1 pm</u>	
24b. Analyzed By:			
24c. QC By:			