


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8TIME 800LOCATION P589 M DATE 3/26/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside							
Playground N		46.0	34.1	380	1	19	0
Playground S		45.8	34.6	383	1	17	0
SE Corner		45.1	35.0	389	1	18	0
East Side		44.9	35.3	392	1	20	0
NE Corner		44.5	35.9	398	1	19	0
North Exit		44.0	36.2	402	1	18	0
NW Corner		43.6	36.5	405	1	19	0
By Air Intake		43.1	37.1	400	1	20	0
SW Corner		42.6	37.5	396	1	21	0
South Exit		42.1	37.9	391	1	18	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8


TIME 830

LOCATION PS89M DATE 3/26/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Stair		69.0	25.8	443	0	16	0
132		69.4	26.1	455	0	14	0
132B		70.0	26.2	464	0	15	0
132C		70.5	26.2	456	0	13	0
132D		70.9	25.9	460	0	12	0
Hall North Exit		70.3	25.4	437	0	18	0
Hall by Cafeteria		70.1	24.8	396	0	16	0
Cafeteria		69.8	24.8	447	0	15	0
South Exit		69.9	24.4	492	0	14	0
Hall by Elevator		70.0	24.6	514	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 3/26/02


CITY_21MC100_006739363

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8TIME 900LOCATION P589 M DATE 3/26/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Kitchen Area.		70.0	26.7	449	0	14	0
501 (Hall)		71.2	24.9	487	0	14	0
502	2	71.0	24.6	483	0	16	0
Hall by Stair 3		71.1	24.3	472	0	13	0
504	31	71.8	27.7	948	0	16	0
Hall by Elevator	5	71.9	25.6	680	0	14	0
506	21	72.3	27.7	989	0	17	0
515		72.0	24.4	536	0	15	0
509 (Hall)		71.9	24.0	523	0	15	0
508 (Hall)		71.9	24.0	516	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8


TIME 930

LOCATION P589 M DATE 3/26/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
510	32	72.6	30.1	1226	0	20	0
512 (Hall)		72.8	24.6	634	0	17	0
Hall by Stair 2	-	72.5	23.8	502	0	15	0
526	1	72.1	23.5	541	0	14	0
528	28	71.8	26.9	870	0	15	0
517		71.5	24.4	578	0	14	0
530 (Hall)		71.4	22.8	489	0	14	0
532	23	71.6	26.0	706	0	14	0
519	10	72.0	26.3	809	0	15	0
Hall by Stair 1		71.7	25.4	683	0	15	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/26/02

CITY_21MC100_006739365


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 1000LOCATION PS89 M DATE 3/26/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
419	3	71.3	23.3	479	0	15	0
432		71.5	23.6	516	0	~~14~~ 13	0
430 (Hall)		71.5	23.4	490	0	15	0
430		71.4	23.4	478	0	14	0
428		71.2	22.6	398	0	13	0
426	25	72.0	27.9	897	0	20	0
Hall by stair 2	—	71.9	25.0	651	0	17	0
410 (Hall)	10	72.0	24.5	593	0	15	0
408	18	72.3	26.1	1061	0	17	0
415	1	71.6	24.4	656	0	18	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8TIME 1030LOCATION PS89 M DATE 3/26/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Elevator		72.0	23.9	593	0	16	0
404	29	72.6	28.7	1338	0	25	0
402	1	71.4	23.6	640	0	16	0
401	16	71.4	23.7	600	0	12	0
301	16	71.7	23.7	560	0	9	0
302	1	72.1	23.6	520	0	12	0
304 (Hall)		72.1	23.7	528	0	17	0
306	2	72.3	23.6	563	0	16	0
315 (Hall)		72.2	23.4	516	0	17	0
Gym		70.2	23.7	488	0	19	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____


The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: J. Ch Date: 3/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8TIME 1100LOCATION P589 M DATE 3/26/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
308 (Hall)		70.3	23.5	470	0	17	0
310		71.0	22.9	462	0	18	0
314 (Hall)		70.9	23.4	467	0	16	0
316	2	70.8	23.1	483	0	17	0
324 (Hall)		70.9	23.5	472	0	17	0
326		71.4	23.6	468	0	12	0
328 (Hall)		71.1	23.6	474	0	17	0
330		71.3	23.8	707	0	17	0
332	18	71.5	24.1	553	0	13	0
319		71.6	23.3	485	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1130LOCATION PS89 M DATE 3/26/02 PROJECT NO. 19125-297

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
232	20	72.1	25.5	739	0	17	0
219		72.5	24.4	573	0	20	0
230 (Hall)		72.6	23.3	499	0	16	0
217C (Hall)		72.5	23.2	490	0	16	0
228	12	72.4	24.2	563	0	14	0
208 (Hall)		71.8	22.7	466	0	16	0
Auditorium	8	71.2	22.4	463	0	16	0
204	1	71.0	24.3	727	0	13	0
202	1	71.4	24.7	660	0	18	0
201		71.6	24.0	580	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 3/26/02