


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8TIME 800LOCATION PS89 M DATE 3/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<u>Outside</u>							
<u>Playground N.</u>		<u>50.0</u>	<u>39.9</u>	<u>400</u>	<u>1</u>	<u>25</u>	<u>0</u>
<u>Playground S</u>		<u>49.8</u>	<u>40.3</u>	<u>408</u>	<u>1</u>	<u>24</u>	<u>0</u>
<u>SE Corner</u>		<u>49.5</u>	<u>40.7</u>	<u>399</u>	<u>1</u>	<u>25</u>	<u>0</u>
<u>East Side</u>		<u>49.1</u>	<u>41.0</u>	<u>391</u>	<u>1</u>	<u>26</u>	<u>0</u>
<u>NE Corner</u>		<u>48.8</u>	<u>41.4</u>	<u>396</u>	<u>1</u>	<u>24</u>	<u>0</u>
<u>North Exit</u>		<u>48.6</u>	<u>41.1</u>	<u>401</u>	<u>1</u>	<u>25</u>	<u>0</u>
<u>NW Corner</u>		<u>48.3</u>	<u>41.4</u>	<u>406</u>	<u>1</u>	<u>23</u>	<u>0</u>
<u>By Air Intake</u>		<u>48.0</u>	<u>42.0</u>	<u>411</u>	<u>1</u>	<u>23</u>	<u>0</u>
<u>SW Corner.</u>		<u>48.3</u>	<u>41.8</u>	<u>408</u>	<u>1</u>	<u>24</u>	<u>0</u>
<u>South Exit</u>		<u>48.6</u>	<u>41.6</u>	<u>398</u>	<u>1</u>	<u>25</u>	<u>0</u>
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/27/02

CITY_21MC100_006739374


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8TIME 830LOCATION PS89 M DATE 3/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Stair 1		72.3	33.0	560	1	13	0
132		72.0	32.8	528	1	10	0
132B		72.2	33.0	501	1	10	0
132C		72.4	33.1	510	1	10	0
132D		72.2	32.9	500	1	10	0
North Exit		72.4	32.0	484	1	14	0
Dance Rm		72.5	33.3	514	1	10	0
Hall by Cafeteria		73.0	31.5	475	1	15	0
Cafeteria		71.8	31.6	528	1	13	0
South Exit		71.3	31.0	512	1	17	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/27/02

CITY_21MC100_006739375


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8TIME 900LOCATION PS89 M DATE 3/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
501	4	73.1	31.5	506	1	8	0
502 (Hall)		73.6	31.3	522	1	11	0
504	3	73.5	31.6	568	1	14	0
Hall by Elevator		73.5	31.6	626	1	16	0
506	2	73.4	32.4	590	1	18	0
515 (Hall)		73.5	31.0	584	1	74	0
508 (Hall)		73.6	31.4	602	1	16	0
510	28	73.6	31.6	899	1	14	0
512	3	74.4	32.4	733	1	16	0
Hall by Stair 2		74.5	31.5	654	1	17	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/27/02


CITY_21MC100_006739376

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8TIME 930LOCATION PS89M DATE 3/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
526	26	73.8	31.9	689	1	14	0
528	21	73.6	31.9	730	1	16	0
517		73.4	31.4	629	1	13	0
530 (Hall)		73.7	32.4	820	1	21	0
519	12	73.4	31.8	899	1	14	0
532	28	73.2	31.4	980	1	16	0
Stair 1		73.3	31.4	638	1	49	0
419 (Hall)		73.3	30.5	604	1	12	0
432		73.1	30.4	530	1	11	0
430 (Hall)		73.0	29.7	504	1	12	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/27/02

CITY_21MC100_006739377


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 1000LOCATION PS89 M DATE 3/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
430 428	3	73.3	30.4	529	1	10	0
428 (Hall)		73.1	29.5	518	1	12	0
426		73.2	30.2	523	1	13	0
Hall by Stair 2		73.3	30.1	565	1	14	0
410 (Hall)		73.4	31.6	706	1	19	0
408	1	73.0	31.9	578	1	12	0
406 (Hall)		73.4	32.4	775	1	16	0
404	26	73.8	32.9	756	1	20	0
402	16	73.8	33.1	762	1	23	0
401 (Hall)		74.0	31.8		1	12	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/27/02

ATC ASSOCIATES, INC.

Page 6 of 8TIME 1030

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS89 M DATE 3/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
302	1	73.9	29.4	474	1	8	0
301 (Hall)	-	73.9	29.3	510	1	11	0
304	2	74.2	29.9	534	1	11	0
306	13	73.9	29.9	538	1	10	0
Hall by Elevator		73.8	29.4	520	1	11	0
315	Full	72.0	28.9	476	1	12	0
315 (Hall)		72.1	29.2	468	1	15	0
308		73.5	29.5	475	1	9	0
310		73.3	29.1	470	1	11	0
314 (Hall)		72.9	29.2	468	1	11	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jim Chen Date: 3/27/02

CITY_21MC100_006739379

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8


TIME 1100

LOCATION P589 M DATE 3/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
316 (HALL)		73.1	28.7	461	1	12	0
326	17	73.3	30.4	590	1	12	0
328	12	73.0	29.9	594	1	8	0
330	15	72.9	30.5	587	1	10	0
332	19	72.8	30.2	666	1	9	0
319 (HALL)		72.6	29.8	594	1	11	0
232	11	73.3	29.9	614	1	11	0
219 (HALL)		73.5	29.3	537	1	11	0
230	12	73.3	29.8	596	1	14	0
217C (HALL)		73.4	29.4	567	1	10	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/27/02

CITY_21MC100_006739380

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1130LOCATION PS89 M DATE 3/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
228(Hall)		73.6	29.4	549	1	10	0
228	11	73.6	29.5	640	1	15	0
217(Hall)		73.7	29.6	610	1	11	0
226	9	74.3	30.2	555	1	13	0
Hall by Stair 2		74.1	28.6	523	1	9	0
208(Hall)		73.6	28.4	510	1	10	0
Auditorium		72.3	27.2	456	1	9	0
204	22	73.4	30.8	639	1	10	0
201(Hall)		73.8	29.8	560	1	10	0
202	15	73.9	30.3	610	1	12	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jiri Ce Date: 3/27/02