

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8TIME 8:00LOCATION PS89 M DATE 4/15/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside							
South Exit		68.0	57.1	491	2	32	0
SE Corner		68.1	57.3	486	2	30	0
East Side		67.8	57.6	490	2	34	0
NE Corner		67.5	58.0	494	2	29	0
North Exit		67.3	58.5	498	2	34	0
NW Corner		67.6	58.9	503	2	30	0
By Air Intake		67.4	59.3	489	2	28	0
SW Corner		67.1	60.0	507	2	31	0
Playground N		67.4	62.3	513	2	30	0
Playground S		67.3	63.0	509	2	32	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 4/15/02

CITY_21MC100_006739409

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8TIME 830LOCATION PS89 MDATE 4/15/02PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Hall by Cafeteria		71.1	64.6	560	2	23	0
Cafeteria		71.6	63.8	660	2	18	0
Dance Room		71.7	60.0	515	2	13	0
North Exit		71.6	61.1	530	2	19	0
132 (Hall)		71.2	61.2	517	2	24	0
Hall by Stair 2		71.1	61.2	538	2	24	0
South Exit		72.2	60.7	548	2	24	0
Hall by Stair 3		72.3	60.6	569	2	24	0
107 (Hall)		72.6	59.9	566	2	23	0
Hall by Elevator		72.5	59.4	570	2	23	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: J. Ch Date: 4/15/02

CITY_21MC100_006739410

ATC ASSOCIATES, INC.

Page 3 of 9


TIME 900

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS89 M DATE 4/15/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
501	2	76.1	54.4	530	2	14	0
502	26	75.9	53.1	718	2	18	0
501 (hall)	-	75.1	58.8	870	2	24	0
504 (hall)	-	76.0	54.1	738	2	23	0
506	-	75.9	52.1	642	2	18	0
515 (hall)	-	75.6	53.8	764	2	23	0
508	30	76.1	53.9	845	2	36	0
510	28	77.0	57.0	1160	2	26	0
512 (hall)	-	75.6	52.7	789	2	24	0
Hall by Stair 2	-	75.6	52.3	687	2	24	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/15/02


CITY_21MC100_006739411

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8TIME 930LOCATION PS89 M DATE 4/15/05 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
526	30	76.1	54.1	885	2	15	0
528	28	76.0	54.3	980	2	22	0
517	1	75.5	50.6	587	2	19	0
530 (Hall)	—	75.3	51.2	637	2	21	0
532	28	75.6	52.5	740	2	21	0
519	11	75.7	52.2	844	2	18	0
Hall by stair 1	—	75.8	53.2	806	2	21	0
419	—	74.8	51.5	602	2	19	0
432	—	74.9	49.6	564	2	11	0
419 (Hall)		75.0	51.6	576	2	22	0
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/15/05

CITY_21MC100_006739412

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 1000LOCATION P589 M DATE 4/15/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
420	1	75.0	50.5	611	2	13	0
428 (Hall)		75.0	53.1	65	3	21	0
426	1	75.3	51.6	630	3	18	0
Hall by Stair 2	-	75.4	53.2	647	3	23	0
410 (Hall)		75.7	53.7	648	3	22	0
408	30	77.0	56.8	1120	3	15	0
415	1	76.0	50.3	660	3	20	0
Hall by Elevator	-	76.1	52.5	683	3	22	0
404	29	77.3	56.0	1097	3	24	0
401	-	77.0	44.2	566	3	14	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 4/15/02

CITY_21MC100_006739413


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8TIME 1030LOCATION PS89 M DATE 4/15/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
401 (Hall)	-	76.5	51.9	662	3	22	0
402	28	77.3	55.3	1290	3	24	0
301	-	77.1	48.2	563	3	14	0
302	16	77.3	50.6	802	3	19	0
304	14	78.0	50.6	810	3	18	0
Hall by Stair 3	-	77.2	49.6	626	3	19	0
306	19	78.2	49.2	940	3	22	0
307 (Hall)		77.5	49.2	663	3	19	0
315	36	76.5	50.0	636	3	22	0
315 (Hall)		77.2	49.5	654	3	20	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/15/02

CITY_21MC100_006739414

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8TIME 11:00LOCATION PS89 MDATE 4/15/00PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
308	—	76.9	48.2	589	3	15	0
310	2	78.0	49.1	549	3	14	0
314 (hall)	—	77.0	49.5	619	3	19	0
316	1	78.0	49.1	634	3	10	0
Hall by Stair 2	—	71.1	49.2	583	3	19	0
326	18	77.2	50.0	826	3	15	0
328	15	76.9	49.9	812	3	14	0
330	15	76.6	49.7	874	3	15	0
332	15	76.2	49.9	783	3	12	0
319 (hall)	—	75.7	49.2	637	3	18	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 4/15/00

CITY_21MC100_006739415


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8

TIME 1130LOCATION PS89 M DATE 4/15/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
219	-	74.5	48.1	586	3	13	0
232	17	74.5	50.0	627	3	22	0
230	10	74.8	49.7	764	3	12	0
217C (Hall)	-	74.6	50.8	702	3	17	0
228	15	75.3	51.2	820	3	15	0
226 (Hall)		75.0	51.1	639	3	18	0
217 (Auditorium)		74.6	51.8	530	3	19	0
204	25	77.0	52.9	1049	3	10	0
202	22	77.3	52.7	760	3	17	0
201 (Hall)		76.6	51.0	612	3	19	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/15/02

CITY_21MC100_006739416