

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8

TIME 800

LOCATION PS89 M DATE 5/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
<u>Outside</u> <small>AM READING</small>							
<u>South Exit</u>		<u>59.3</u>	<u>57.2</u>	<u>550</u>	<u>2</u>	<u>90</u>	<u>0.0</u>
<u>SE Corner</u>		<u>59.0</u>	<u>57.5</u> ✓	<u>546</u>	<u>2</u>	<u>92</u>	<u>0.0</u>
<u>East</u>		<u>59.2</u>	<u>57.4</u>	<u>540</u>	<u>2</u>	<u>92</u>	<u>0.0</u>
<u>NE Corner</u>		<u>58.5</u>	<u>57.1</u>	<u>538</u>	<u>2</u>	<u>88</u>	<u>0.0</u>
<u>North Exit</u>		<u>58.0</u>	<u>57.6</u>	<u>532</u>	<u>2</u>	<u>93</u>	<u>0.0</u>
<u>NW Corner</u>		<u>58.1</u>	<u>57.4</u>	<u>525</u>	<u>2</u>	<u>89</u>	<u>0.0</u>
<u>By Air Intake</u>		<u>58.4</u>	<u>57.0</u>	<u>540</u>	<u>2</u>	<u>95</u>	<u>0.0</u>
<u>SW Corner</u>		<u>58.1</u>	<u>56.8</u>	<u>545</u>	<u>2</u>	<u>89</u>	<u>0.0</u>
<u>Playground S</u>		<u>58.5</u>	<u>56.6</u>	<u>541</u>	<u>2</u>	<u>96</u>	<u>0.0</u>
<u>Playground N</u>		<u>58.7</u>	<u>56.3</u> ✓	<u>543</u>	<u>2</u>	<u>95</u>	<u>0.0</u>
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 5/6/02

CITY_21MC100_006739552

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8TIME 830LOCATION PS89 MDATE 5/6/04PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
South Exit		71.1	45.2	576	1	38	0.0
Hall by Elevator		70.5	44.3	623	1	42	0.0
Cafeteria		70.5	44.1	624	1	39	0.0
Hall by Cafeteria		70.9	43.4	571	1	34	0.0
North Exit		70.8	43.0	554	1	34	0.0
Dance Rm		70.9	42.5	569	1	17	0.0
132B	1	69.9	42.2	563	1	35	0.0
132C		69.8	42.2	574	1	28	0.0
132D		69.9	41.9	584	1	24	0.0
Star 1 (Hall)		69.5	42.0	564	1	38	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 5/6/04

CITY_21MC100_006739553


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8TIME 900LOCATION PS89 M DATE 5/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
501	3	73.5	40.0	547	1	19	0.0
501 (HALL)		73.5	40.8	635	1	30	0.0
502		73.0	40.0	563	1	20	0.0
Hall by Stair 3		73.1	41.2	699	1	31	0.0
504 (HALL)		73.3	41.5	809	1	34	0.0
506		73.6	40.9	720	1	28	0.0
515 (HALL)		73.7	41.5	806	1	34	0.0
508	22	74.1	41.7	898	1	32	0.0
510 (HALL)		74.0	42.4	922	1	36	0.0
512	2	73.9	40.5	778	1	33	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 5/6/02

CITY_21MC100_006739554

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8


TIME 930

LOCATION PS89 M DATE 5/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Hall by Stair 2		74.0	40.4	829	1	30	0.0
526	20	74.2	39.3	722	1	28	0.0
528	24	73.8	40.6	830	1	31	0.0
517 (Hall)		73.6	40.6	840	1	35	0.0
532	28	73.6	40.0	862	1	30	0.0
519	6	73.5	38.3	859	1	26	0.0
Stair 1 (Hall)		73.5	38.8	818	1	35	0.0
419 (Hall)		72.8	39.0	650	1	31	0.0
419		73.1	38.6	615	1	27	0.0
432		72.8	37.3	588	1	18	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 5/6/02

CITY_21MC100_006739555


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 1000LOCATION PS89 M DATE 5/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
430	2	72.8	34.2	635	1	24	0.0
428		72.6	37.6	672	1	24	0.0
426 (Hall)		72.8	37.9	673	1	35	0.0
426		73.1	39.1	660	1	26	0.0
Hall by Stair 2		73.3	39.4	644	1	36	0.0
410 (Hall)		73.7	41.5	822	1	38	0.0
408	30	74.0	42.2	815	1	32	0.0
406 (Hall)		73.0	41.5	831	1	33	0.0
404	24	74.3	41.6	874	1	20	0.0
401		74.2	40.0	699	1	21	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 5/6/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8TIME 109cLOCATION PS89 M DATE 5/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
402	29	74.1	42.6	979	1	40	0.0
301 (Hall)		73.7	39.5	682	1	32	0.0
302	13	73.8	38.5	690	1	21	0.0
304	16	74.4	39.0	698	1	31	0.0
Stair 3 (Hall)		74.3	39.2	666	1	34	0.0
306	16	74.5	39.0	666	1	32	0.0
313 (Hall)		74.3	39.2	633	1	35	0.0
315		74.5	39.4	627	1	33	0.0
308	3	74.6	39.2	651	1	38	0.0
310	2	75.0 ✓	38.6	615	1	31	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 5/6/02

CITY_21MC100_006739557

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8

TIME 1100

LOCATION PS89 M DATE 5/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
314 (Hall)		74.9	38.8	630	1	34	0.0
316 (Hall)		74.6	38.6	616	1	35	0.0
Stair 2 (Hall)		74.4	38.6	612	1	35	0.0
326	18	74.4	38.8	713	1	28	0.0
328	14	73.7	38.7	726	1	36	0.0
330	14	73.1	38.5	682	1	32	0.0
332	19	72.8	38.7	765	1	25	0.0
319		72.6	38.7	593	1	20	0.0
Hall Stair ¹ ₃		72.5	37.3	609	1	25	0.0
Stair 1		72.4	38.9	670	1	32	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 5/6/02

CITY_21MC100_006739558


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1130LOCATION PS89M DATE 5/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
232	18	71.7	38.6	752	1	18	0.0
219		71.6	38.7	662	1	22	0.0
230	9	72.0	38.7	706	1	15	0.0
228	14	72.4	39.9	758	1	28	0.0
226	13	73.3	41.0	725	1	15	0.0
Stair 2 (Hall)		73.4	40.4	709	1	28	0.0
208 (Hall)		73.6	41.0	700	1	30	0.0
Auditorium		74.2	37.6	603	1	24	0.0
204	24	74.9	40.5	801	1	20	0.0
Playground S		65.3 ✓	44.4	536	2	88	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 5/6/02

CITY_21MC100_006739559