

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 2

TIME 815

LOCATION PS/IS89M

DATE 5/17/02

PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside							
AM Reading South Exit		68.6	49.0	449	2	58	0.0
AM Reading In by Main Desk		71.5	46.8	504	2	36	0.0
SE		68.4	49.2	445	2	58	0.0
East		68.1	49.5	440	2	60	0.0
NE		68.5	49.7	437	2	61	0.0
North Exit		68.7	50.0	435	2	60	0.0
NW		68.5	49.6	437	2	58	0.0
SW		68.3	49.9	440	2	60	0.0
Playground S		68.0	49.6	436	2	62	0.0
Playground N		68.2	49.5	434	2	60	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____ Date: 5/17/02

CITY_21MC100_006739610

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 2

TIME 8:30

LOCATION PS/IS89M


DATE 5/17/02

PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Cafeteria		74.5	43.2	498	2	30	0.0
Hall by Cafeteria		74.5	42.7	487	2	28	0.0
North Exit		74.2	42.5	495	2	29	0.0
Dance Rm		74.2	43.7	470	2	32	0.0
132	1	74.0	41.4	498	2	23	0.0
132B	1	74.1	41.8	490	2	20	0.0
132C		74.3	41.6	484	2	15	0.0
132D		74.3	41.3	485	2	14	0.0
Stair 1 (Hall)		74.1	42.8	516	2	28	0.0
Elevator (Hall)		72.7	43.6	484	2	35	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 5/17/02

CITY_21MC100_006739611

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8TIME 900LOCATION PS/IS89MDATE 5/17/02PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
501		76.0	40.7	488	2	20	0.0
501 (Hall)		75.9	40.6	579	2	21	0.0
502	1	75.9	41.2	530	2	24	0.0
Stair 3 (Hall)		76.1	40.3	500	2	22	0.0
504	30	77.0	47.6	1160	2	30	0.0
Hall by Elevator		77.1	41.2	735	2	24	0.0
506 (Hall)		77.1	40.3	595	2	23	0.0
509 (Hall)		76.8	39.5	530	2	23	0.0
515	3	77.1	38.9	644	2	10	0.0
508 (Hall)		76.9	39.2	528	2	25	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jung Chang Date: 5/17/02

CITY_21MC100_006739612

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8

TIME 930

LOCATION PS/IS89M

DATE 5/17/02

PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
510	4	77.6	41.1	615	2	30	0.0
512 (Hall)		77.2	39.1	547	2	26	0.0
Stair 2 (Hall)		77.1	38.9	542	2	27	0.0
526	31	77.5	41.8	1087	2	26	0.0
528 (Hall)		77.4	38.6	546	2	30	0.0
517	3	77.6	38.8	550	2	24	0.0
532	32	77.9	42.3	1034	2	28	0.0
Stair 1 (Hall)		77.7	40.4	770	2	30	0.0
519	10	77.5	40.4	740	2	31	0.0
Stair 1		76.3	38.2	601	2	26	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: Jay Chy Date: 5/17/02

CITY_21MC100_006739613

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 1000LOCATION PS/IS89MDATE 5/17/02PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
419	1	76.4	38.4	515	2	14	0.0
419 (Hall)		76.6	39.3	650	2	22	0.0
432	16	77.1	40.3	738	2	22	0.0
430 (Hall)		77.1	39.5	655	2	25	0.0
428 (Hall)		77.2	39.3	575	2	30	0.0
426 (Hall)		77.3	39.4	567	2	26	0.0
Stair 3 (Hall)		77.5	39.4	560	2	30	0.0
410 (Hall)		77.7	39.0	538	2	27	0.0
408 (Hall)		77.6	39.0	560	2	30	0.0
404	27	78.4	43.7	1290	2	20	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jim Lin Date: 5/17/02

CITY_21MC100_006739614

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8TIME 1030LOCATION PS/IS89MDATE 5/17/02 PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
402	29	78.3	43.5	1240	2	27	0.0
401 (Hall)		78.1	40.0	824	2	24	0.0
301	17	77.4	38.8	625	2	24	0.0
302 (Hall)		77.8	38.8	621	2	31	0.0
302	15	77.4	40.6	852	2	30	0.0
Stair 3 (Hall)		77.9	39.5	661	2	30	0.0
304	15	78.1	39.2	649	2	25	0.0
Elevator (Hall)		78.1	39.6	619	2	30	0.0
306	17	78.2	38.7	607	2	20	0.0
315 (Hall)		78.0	39.8	614	2	30	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jay C. [Signature] Date: 5/17/02


CITY_21MC100_006739615

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8TIME 1100LOCATION PS/IS89MDATE 5/17/02 PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Gym	24	78.0	39.9	620	2	30	0.0
308	4	78.2	38.4	655	2	18	0.0
310	3	78.5	38.0	616	2	11	0.0
314 (Hall)		78.3	39.6	624	2	30	0.0
312 (Hall)		78.1	39.3	617	2	30	0.0
326	18	78.5	39.9	652	2	28	0.0
Stair 2 (Hall)		78.1	39.2	603	2	30	0.0
328	14	77.8	39.2	628	2	32	0.0
330	2	77.3	39.2	658	2	20	0.0
Playground N		74.8	40.9	429	2	34	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____


The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 5/17/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1130LOCATION PS/IS89MDATE 5/17/02PROJECT NO. 19125-0297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
332	17	77.3	40.0	973	2	24	0.0
314	4	76.6	38.7	612	2	30	0.0
214	18	76.0	42.0	878	2	28	0.0
232	11	76.5	40.5	938	2	17	0.0
230	13	76.6	41.2	1036	2	22	0.0
228	16	76.9	41.5	1020	2	22	0.0
226 (hall)		76.9	40.1	695	2	28	0.0
204	18	77.0	40.9	1050	2	30	0.0
202	23	77.4	42.0	868	2	28	0.0
201 (hall)		77.2	40.0	645	2	27	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 5/17/02

CITY_21MC100_006739617