


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 1420LOCATION PS 234 M DATE 4/17/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside							
745 Main Entrance		81.3	49.0	680	2	124	0
745 Inside by Main Desk		78.3	43.3	703	2	81	0
NE Corner		85.0	39.0	580	7	167	0
Main Entrance		85.3	40.0	585	7	165	0
SE Corner		85.6	40.5	600	7	161	0
Courtyard		85.8	41.1	619	7	158	0
NW Corner		86.0	41.6	601	7	156	0
West Side		86.3	41.9	598	7	158	0
SW Corner		86.8	42.3	590	7	161	0
South Side		87.3	43.0	586	7	160	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/17/02

CITY_21MC100_003032270

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6TIME 1430LOCATION PS 234 M DATE 4/17/02 PROJECT NO. 19125-279

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Main Foyer		79.2	44.7	777	2	119	0
Main Desk		79.3	44.3	888	2	69	0
Hall by Gym		78.2	43.3	909	2	65	0
Gym	22	77.5	43.4	966	2	68	0
Cafeteria		76.1	38.7	894	2	65	0
Hall by Elevator		76.0	43.8	856	2	76	0
Hall by Exit		75.5	44.6	830	2	80	0
114 (hall)		75.1	46.0	863	2	88	0
116	15	74.3	45.5	938	2	82	0
118	24	73.1	50.0	1009	2	70	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jimmy Chen Date: 4/17/02

CITY_21MC100_003032271

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6TIME 1500LOCATION PS 234 M DATE 4/17/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
120 (wall)	-	74.9	48.7	810	2	88	0
122		73.8	49.2	718	2	92	0
Hallway stair 3	-	74.8	48.5	806	2	90	0
222	24	73.6	47.8	980	2	70	0
220		72.6	48.2	835	2	68	0
220 (wall)		72.7	49.6	805	2	84	0
218 (window open)	22	73.6	50.9	809	2	112	0
216	26	72.6	49.8	942	2	64	0
212 (wall)		72.6	50.7	852	2	100	0
229	26	73.1	49.3	1118	1084	40	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 4/17/02

CITY_21MC100_003032272


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6TIME 1530LOCATION PS 234 M DATE 4/17/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
225	2	73.7	51.3	984	2	50	0
227 (Hall)		73.3	51.5	900	~~2~~ 2	90	0
210	3	72.5	49.4	930	2	57	0
Hall by Stair 1	-	72.4	50.4	890	2	78	0
223 (Hall)	-	72.5	50.8	870	2	75	0
219	-	72.5	49.7	976	2	46 ~~4~~	0
206	-	74.1	51.0	888	2	58	0
215	1	74.1	50.4	925	2	54	0
211	-	73.8	49.6	849	2	39	0
206 (Hall)	-	73.7	49.4	909	2	47	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/17/02

CITY_21MC100_003032273

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 1600LOCATION PS 234 M DATE 4/17/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
202		74.3	49.4	893	2	35	0
201		74.3	48.7	907	2	40	0
301		75.6	50.1	970	2	50	0
302 (hall)		76.2	51.0	936	2	74	0
305		76.0	50.5	970	2	46	0
307 (hall)		76.0	50.8	968	2	90	0
304		75.0	48.0	894	2	67	0
311		74.6	49.1	967	2	80	0
306		74.4	49.0	927	2	79	0
315		74.3	48.5	936	2	49	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jerry Chang Date: 4/17/02

CITY_21MC100_003032274


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1630LOCATION PS 234 M DATE 4/17/06 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
308		73.8	48.5	936	2	76	0
319		74.2	44.6	890	2	83	0
323		74.1	49.5	804	2	44	0
310		72.9	48.9	943	2	60	0
325		73.6	51.8	850	2	58	0
324		73.8	51.9	870	2	63	0
316		73.5	52.3	909	2	56	0
318		73.0	52.5	894	2	60	0
320		72.8	50.0	914	2	80	0
322		73.0	51.8	929	2	72	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/17/06

CITY_21MC100_003032275