

ATTACHMENT

IAQ FIELD DATA COLLECTION FORMS

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1

TIME 1400

LOCATION PS234M

DATE 5/16/02

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside							
1st		68.0	24.0	380	2	20	
2nd		68.5	24.3	380	2	18	
3rd		68.0	24.0	380	2	18	
4th		68.0	23.0	371	2	20	
5th		68.0	24.0	386	2	20	
6th		68.0	24.0	348	2	18	
7th		68.0	24.0	404	2	20	
8th		68.0	25.1	408	2	20	
9th		68.5	23.0	390	1	55	
10th		68.0	24.6	304	0	20	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 5/16/02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3

TIME 1430

LOCATION PS234M

DATE 5/16/02

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Cafeteria		72.1	50.4	766	2	20	0.1
Gym		70.0	50.4	776	2	20	0.1
Office (4th)		74.3	50.3	677	2	20	0.1
Ex. 1 (4th)		75.0	48.8	600	2	24	0.1
114 (4th)		73.8	48.9	608	2	20	0.1
116		70.9	50.7	840	2	20	0.1
118		72.0	50.2	742	2	20	0.1
120		73.1	50.1	699	2	20	0.1
122		73.3	50.2	742	2	10	0.1
Stair 3		73.0	50.0	813	2	20	0.1
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/16/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6

TIME 1500

LOCATION PS234M

DATE 5/16/02

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
232 (HALL)		70.8	30.0	780	2	16	0.0
233		70.0	31.0	700	2	16	0.0
234		69.9	31.5	770	2	16	0.0
235		68.7	31.7	720	2	17	0.0
236		68.2	31.6	730	2	15	0.0
237 (HALL)		69.0	32.1	735	2	15	0.0
238		69.8	31.6	724	2	16	0.0
239 (HALL)		71.2	32.4	601	2	16	0.0
235		71.3	32.6	611	2	17	0.0
240 (HALL)		71.0	32.2	600	2	17	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/16/02

CITY_21MC100_003032503

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6

TIME 15:00

LOCATION PS234M

DATE 5/16/06

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
203		71.4	32.5	730	2	10	0.5
214		72.3	32.6	222	2	10	0.5
Plant (Hall)		72.4	32.2	595	2	10	0.5
200		71.7	32.4	630	2	21	0.5
206 (Hall)		73.2	32.8	600	2	16	0.5
25		73.5	32.8	600	2	14	0.5
211		73.0	32.5	611	2	17	0.5
Plant (Hall)		72.2	32.6	593	2	16	0.5
207		72.5	32.6	615	2	10	0.5
202		72.4	32.3	722	2	16	0.5
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 5/16/06

CITY_21MC100_003032504

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 1600LOCATION PS234MDATE 5/16/02 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
301		73.8	32.2	630	1	16	0.5
302 (Hall)		74.3	32.5	635	1	15	0.5
302		74.1	32.0	626	1	8	0.5
303		71.4	31.2	619	1	15	0.5
304		71.5	32.1	620	1	14	0.5
311		71.6	30.9	619	1	15	0.5
306		71.6	31.3	611	1	14	0.5
315		71.9	31.4	580	1	20	0.5
308		71.3	31.4	583	1	24	0.5
319		71.5	31.2	571	1	20	0.5
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/16/02

CITY_21MC100_003032505

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6

TIME 1630

LOCATION PS234M

DATE 5/16/02

PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
323		71.6	31.9	583	1	14	0.5
316		71.8	32.1	580	1	20	0.5
430-1		71.6	32.0	575	1	18	0.5
325		71.3	32.0	640	1	16	0.5
324		71.9	32.4	574	1	12	0.5
316		72.2	32.1	570	1	14	0.5
318		72.0	32.0	566	1	18	0.5
326		72.4	33.3	660	1	16	0.5
322		72.1	33.7	654	1	14	0.5
Stair 3		72.2	32.9	683	1	12	0.5
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____ Date: 5/16/02

CITY_21MC100_003032506