

ATTACHMENT

IAQ FIELD DATA COLLECTION FORMS

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6Time: 7:00 AMLOCATION: PS 234DATE: 6/25/02PROJECT NO: 19125-

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
CUTSIDE							
MAIN ENTRANCE	0	80.3	57.3	610	1	101	0
NEXT TO MAIN DESK	0	80.2	57.1	641	1	101	0
NORTHWEST CORNER	0	80.1	57.1	599	1	99	0
WESTSIDE	0	80.1	57.1	586	1	96	0
SOUTHWEST CORNER	0	80.4	57.1	571	1	100	0
COURTYARD	0	80.4	57.1	631	1	100	0
NORTH EAST CORNER	0	80.2	57.1	620	1	92	0
MAIN ENTRANCE	0	80.2	57.6	616	1	98	0
SOUTHEAST CORNER	0	80.1	56.9	650	1	98	0
SOUTH SIDE	0	80.3	56.9	661	1	93	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/25/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page ²~~5~~ of ~~10~~ 6

Time: 11:01 AM

LOCATION: PS 234

DATE: 6/25/02 PROJECT NO: 19185-

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
CATFCTRIA	4	73.1	53.6	709	1	36	0
HALL BY Gym	10	74.1	54.4	826	1	39	0
Gym	2	73.9	52.6	609	1	39	0
MAIN FOYER	1	75.1	54.6	599	1	44	0
MAIN DESK	1	75.2	59.8	610	1	42	0
HALL BY elevator	2	75.1	58.6	616	1	36	0
HALL BY EXIT 1	3	74.9	54.6	714	1	40	0
HALLWAY 114 NEXT TO Rm	4	74.1	55.6	727	1	41	0
116	26	76.1	51.9	1261	1	42	0
118	20	75.1	51.6	1014	1	40	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/25/02

CITY_21MC100_003032799

**ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT**

Page 3 of 6

Time: 11:30 AM

LOCATION: PS 234

DATE: 6/25/02 PROJECT NO: 19125-

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
323	18	74.8	51.6	1136	1	30	0
325	0	74.6	53.6	610	1	33	0
310	0	75.1	54.6	586	1	28	0
324	0	74.9	52.4	602	1	20	0
312 Hallway	1	75.1	52.8	610	1	19	0
316	24	74.3	53.1	1039	1	26	0
318	22	73.6	53.6	1136	1	26	0
320	26	73.4	54.1	1181	1	28	0
322	24	72.4	50.9	1156	1	18	0
NEXT TO STAIRS #3 Hallway	3	75.3	52.3	707	1	17	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/25/02

CITY_21MC100_003032800

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6

Time: 12⁰⁰pm

LOCATION:

PS 234

DATE:

6/25/02

PROJECT NO:


19125

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
HALLWAY NEXT TO PM 210	0	74.6	52.6	610	1	26	0
225	26	74.9	53.4	1241	1	19	0
223	21	75.3	54.1	1133	1	16	0
NEXT TO ELEVATOR BANK 2ND FLOOR	3	75.1	54.1	719	1	28	0
214	0	74.6	52.3	605	1	31	0
206	0	73.6	51.6	586	1	30	0
206 HALLWAY	1	75.6	53.1	621	1	30	0
215	0	74.4	51.1	621	1	28	0
211	30	74.3	50.9	1342	1	30	0
201	4	74.6	54.3	909	1	32	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:



Date:

6/25/02

**ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT**

Page 5 of 6

Time: 12:31 pm LOCATION: PS 234 DATE: 6/25/02 PROJECT NO: 19125-

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
202	2	74.6	51.6	620	1	28	0
301	4	73.9	51.3	749	1	26	0
Hallway 302	1	75.1	53.1	608	1	20	0
305	0	73.6	51.6	586	1	19	0
304	21	73.9	52.3	1141	1	16	0
311	0	74.1	52.3	561	1	22	0
306	2	74.1	54.1	628	1	24	0
315	0	74.9	53.6	581	1	28	0
308	15	73.9	54.6	810	1	29	0
319	21	72.9	50.1	1030	1	16	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/25/02

CITY_21MC100_003032802

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6

Time: 12:51 pm LOCATION: PS 234 DATE: 6/25/02 PROJECT NO: 19125

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
HALLWAY NEXT TO STAIRWELL 3	0	74.9	54.6	588	1	21	0
120	0	74.1	50.9	601	1	26	0
122	0	73.9	50.6	586	1	31	0
222	25	73.6	50.1	1261	1	28	0
220	22	75.1	52.6	1169	1	19	0
HALLWAY 218	0	75.5	52.6	587	1	16	0
216	28	76.1	54.9	1209	1	15	0
212	3	76.3	54.1	809	1	20	0
229	27	75.3	53.9	1240	1	22	0
227 HALLWAY	1	75.3	53.1	640	1	27	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: K. [Signature]

Date: 6/25/02