

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-26-02

CLIENT: NYC BOE

PROJECT ADDRESS: PS 1M / 8 Henry St
NY, NY 10038

PROJECT NO: 41617-0905

SAMPLED BY: H. Antonyan

SAMPLE DATE: 08-24-02
DATE RECEIVED: 08-24-02
DATE ANALYZED: 08-24-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
01	9953	Main Lobby (1st Floor) Floor	<9.0	9.0
02	9953	Cafeteria Floor	<9.0	9.0
03	9953	1st Floor Hallway Floor	<9.0	9.0
04	9953	2nd Floor Auditorium Floor	<9.0	9.0
05	9953	2nd Floor Hallway by Rm 213 Floor	<9.0	9.0
06	9953	1st Floor Playarea Floor	<9.0	9.0
07	9953	Rm 213 Window Sill	<10.8	10.8
08	9953	3rd Floor Hallway by Rm 313 Floor	<9.0	9.0
09	9953	4th Floor Hallway by Rm 402 Floor	<9.0	9.0
10	9953	Rm 402 Floor	<9.0	9.0
11	9953	5th Floor Hallway	<9.0	9.0
12	9953	Blank	<9.0 µg	9.0 µg
13	9953	Blank	<9.0 µg	9.0 µg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft²,
Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

TL

REPORT PREPARED BY: _____

Julio

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

Chris

LABORATORY DIRECTOR: _____

M.C.

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP # 0879), (AIHA #100229).