

TIME 8⁰⁰ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORTPage 1 of 5LOCATION PS 2 MDATE 8-23-02 PROJECT NO. 19125-0341

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside school		81.6	61.6	557	2	58	0.2
311	5	84.3	50.5	1046	3	44	0.0
315	19	84.4	50.6	1032	2	41	0.1
317 (A/C)	13	83.4	41.6	1162	2	33	0.1
319 (A/C)	8	82.6	50.4	1043	2	40	0.1
324 (A/C)	15	81.9	49.3	1080	2	44	0.0
307	-	85.1	60.3	654	3	44	0.0
306	-	85.7	60.4	759	3	45	0.0
303	-	85.7	59.2	974	3	45	0.0
Corridor R304	-	85.2	57.6	1030	3	46	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: M. Nakamura Date: 8-23

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 5TIME 8:50LOCATION PS 2MDATE 8-23-02 PROJECT NO. 19125-0341

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Corr. R305	-	86.5	60.0	1157	2	49	0.1
Corr. R318	-	86.3	59.7	1032	2	48	0.1
R 219	7	84.8	45.7	1137	3	49	0.0
R 224	16	85.8	59.5	985	3	36	0.0
R 217	21	85.8	59.5	985	3	38	0.0
R 215	22	85.8	59.5	985	2	49	0.0
R 213	-	85.8	59.5	985	2	43	0.0
R 220	21	85.8	59.5	985	2	40	0.0
R 211	19	85.8	59.5	985	2	37	0.1
R 218	21	85.8	59.5	985	3	43	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: M. Marking Date: 8-23

TIME 9:45ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORTPage 3 of 5LOCATION PS 2 MDATE 8-23-02PROJECT NO. 19125-0341

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Cert. 207	-	85.8	59.5	985	2	40	0.0
Cert 205	-	85.8	59.5	985	2	41	0.0
Cert 203	-	85.8	59.5	985	1	44	0.0
R 204	5	85.8	59.5	1210	3	43	0.0
R 119	13	83.8	47.4	1132	2	38	0.0
Cert. 117	-	84.2	54.7	1010	2	40	0.0
R 115	8	82.7	48.1	1120	2	40	0.1
R 113	21	82.1	45.8	1204	3	42	0.0
R 111	19	83.4	47.9	1120	2	41	0.0
Cert 118	-	83.7	55.7	927	2	42	0.1
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: M. Williams Date: 8-23

TIME 10⁵⁰ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORTPage 4 of 5LOCATION PS 2MDATE 8-23-02 PROJECT NO. 19125-0341

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
R107	2	85.3	59.3	854	2	44	0.0
Corridor 108	—	85.5	58.4	793	2	40	0.0
Corridor 103	—	85.7	53.6	842	3	35	0.1
Cafeteria	5	85.5	62.4	1120	~~3~~ 3	38	0.1
B3	2	87.1	60.6	680	3	43	0.1
B7	—	86.2	59.4	697	3	41	0.1
Corridor B18	—	86.7	59.6	642	3	45	0.1
Corr. B22	—	85.7	56.7	932	2	41	0.0
Gymnasium	—	85.9	56.9	655	2	42	0.0
B19	—	85.9	56.8	1122	2	41	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 8-23

TIME 11:45

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 5

LOCATION PS 2 M

DATE 8-23-02

PROJECT NO. 19125-0341

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
B21	-	85.6	56.3	938	3	44	0.1
B23	-	84.2	53.2	947	2	46	0.1
B25	-	83.1	51.3	947	2	44	0.1
Corr. B25	-	85.6	54.2	948	2	44	0.0
Corr. B21	-	85.6	57.6	947	2	46	0.0
Corr B19	-	85.6	57.6	949	3	40	0.1
Corr. School entr.	-	85.6	57.6	947	3	38	0.1
Auditorium	-	83.2	57.2	910	3	38	0.0
B9	-	84.2	54.1	985	3	40	0.0
Outside	-	82.2	61.8	561	2	57	0.1
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: M. [Signature] Date: 8-23